

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
Division of Water Resources
William R. Snodgrass - Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243-1102

**MS BETHANNE WEYENBERG,
PROJECT MANAGER
ATC GROUP SERVICES, LLC
2690 MEMORIAL BLVD., SUITE D
MURFREESBORO, TN 37129**
e-copy: Bethanne.Weyenberg@atcgs.com
Geina.Skinner@tn.gov

UST Groundwater Remediation NPDES General Permit Notice of Coverage Fact Sheet

The Division of Water Resources received from your company a Notice of Intent (NOI) to be covered under the General NPDES Permit for Discharges of Treated Groundwater Associated with Underground Storage Tank Remediation (UST GP). **We have recorded site information and are hereby notifying you that this groundwater remediation site is covered under the UST GP.**

Enclosed with this fact sheet you will find a Notice of Coverage (NOC) with the permit tracking number (TNG830259), facility's name, address and receiving stream information that apply to your facility/site. In order to get a copy of the UST GP requirements we ask you to visit our web site: <https://www.tn.gov/environment/permit-permits/water-permits1/npdes-permits1/underground-storage-tank-remediation-npdes-general-permit.html>


At our web site, you will be able to download permit requirements, as well as permit rationale, Notice of Determination, guidance documents and find links to relevant web sites. If you do not have access to the web, or have other questions, call us at (888) 891-TDEC or contact us by E-mail at Water.Permits@tn.gov. Thank you for your time and assistance.

Sincerely,



Vojin Janjic
Manager, Water-Based Systems

cc: Division of Underground Storage Tanks, Nashville
Division of Water Resources - Permit File & Jackson EFO



Tracking No. TNG830259

Notice of Coverage under the
General NPDES Permit for Discharges of Treated Groundwater Associated with
UNDERGROUND STORAGE TANK REMEDIATION

Tennessee Department of Environment and Conservation
Division of Water Resources
William R. Snodgrass - Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243-1102

Under authority of the Tennessee Water Quality Control Act of 1977 (T.C.A. 69-3-101 et seq.) and the delegation of authority from the United States Environmental Protection Agency under the Federal Water Pollution Control Act, as amended by the Clean Water Act of 1977 (33 U.S.C. 1251, et seq.):

Discharger: **ATC Group Services, LLC**

Is authorized to discharge: **Treated groundwater associated with underground storage tank remediation**

From a site located at: **8300 Highway 104 North in Lexington, Henderson County
Formerly McGee Grocery
Latitude: 35.749249, Longitude: -88.499285**

To receiving waters named: **Spring Creek**

In accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

Coverage under this general permit shall become effective on **November 20, 2019**

and shall expire on **September 30, 2023**

Notice of Coverage issued: **November 20, 2019**

UST General Permit is located at <https://www.tn.gov/environment/permit-permits/water-permits1/npdes-permits1/underground-storage-tank-remediation-npdes-general-permit.html>

TNG830259

Effective Date: **November 20, 2019**

Expiration Date: **September 30, 2023**

EFFLUENT LIMITS

Discharges covered by this permit must comply with the following numerical effluent limits:

Description: External Outfall, Number: 001, Monitoring: Effluent Gross, Season: All Year, Limit Set Status: Active							
Code	Parameter	Qualifier	Value	Unit	Sample Type	Monitoring Frequency	Statistical Base
00400	pH	>=	6.5	SU	Grab	Quarterly	Daily Minimum
00400	pH	<=	9.0	SU	Grab	Quarterly	Daily Maximum
00530	Total Suspended Solids (TSS)	<=	40	mg/L	Grab	Quarterly	Daily Maximum
01114	Lead, total recoverable	<=	.45	mg/L	Grab	Quarterly	Daily Maximum
34010	Toluene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum
34030	Benzene	<=	.005	mg/L	Grab	Quarterly	Daily Maximum
34371	Ethylbenzene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum
45613	Floating solids or visible foam-visual	>=	-	Y=1;N=0	Visual	Quarterly	Daily Maximum
50050	Flow	Report	-	Mgal/d	Instantaneous	Quarterly	Daily Maximum
81551	Xylene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum
TRP3B	IC25 Static Renewal 7 Day Chronic Ceriodaphnia *	>=	100	% survival	Composite	See Permit	Daily Minimum
TRP6C	IC25 Static Renewal 7 Day Chronic Pimephales promelas *	>=	100	% survival	Composite	See Permit	Daily Minimum

* WET testing will be required if the permittee is not in compliance with any of the numerical effluent limits for Benzene, Ethylbenzene, Toluene, Xylene or Lead, during the first year from the effective date of this coverage. If an exceedance of any effluent limitation is reported, WET testing shall commence within 180 days from the date an exceedance is reported. WET tests shall be performed for three (3) consecutive months using two appropriate species.