



STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION

**401 CHURCH STREET
L & C ANNEX 6TH FLOOR
NASHVILLE TN 37243**

January 8, 2010

Mr. Chip Leonard,
Southeastern Development Group, Inc.
9131 Cross Park Drive
Knoxville, TN 37923

**Re: State Operating Permit No. SOP-09048
Stonebridge Subdivision
Danbridge, Jefferson County, Tennessee**

Dear Mr. Leonard:

In accordance with the provisions of the "Tennessee Water Quality Control Act" (Tennessee Code Annotated Sections 69-3-101 through 69-3-120) the enclosed State Operating Permit is hereby issued by the Division of Water Pollution Control. The continuance and/or reissuance of this Permit is contingent upon your meeting the conditions and requirements as stated therein.

Please be advised that a petition for permit appeal may be filed, pursuant to T.C.A. Section 69-3-105, subsection (i), by the permit applicant or by any aggrieved person who participated in the public comment period or gave testimony at a formal public hearing whose appeal is based upon any of the issues that were provided to the commissioner in writing during the public comment period or in testimony at a formal public hearing on the permit application. Additionally, for those permits for which the department gives public notice of a draft permit, any permit applicant or aggrieved person may base a permit appeal on any material change to conditions in the final permit from those in the draft, unless the material change has been subject to additional opportunity for public comment. Any petition for permit appeal under this subsection (i) shall be filed with the board within thirty (30) days after public notice of the commissioner's decision to issue or deny the permit.

If you have questions, please contact the Division of Water Pollution Control at your local Environmental Field Office at 1-888-891-TDEC; or, at this office, please contact Mr. Hari Akunuri at (615) 532-0650 or by E-mail at Hari.Akunuri@tn.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "V. Janjic".

Vojin Janjic
Manager, Permit Section
Division of Water Pollution Control

Enclosure

cc/ec: Division of Water Pollution Control, Permit Section
Division of Water Pollution Control, Knoxville Environmental Field Office
Mr. Carrol L. Proffitt, Wastewater Manager, Newport Utilities WWTP, cproffitt@newportutilities.com

**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER POLLUTION CONTROL**

**6th Floor, L & C Annex
401 Church street
Nashville, TN 37243-1534**

Permit No SOP-09048

**PERMIT
For the operation of Wastewater Treatment Facilities**

In accordance with the provision of Tennessee Code Annotated section 69-3-108 and Regulations promulgated pursuant thereto:

PERMISSION IS HEREBY GRANTED TO

**Stonebridge Subdivision
Danbridge, Jefferson County, Tennessee**

FOR THE OPERATION OF

A holding tank/haul system to dispose of domestic wastewater from a facility located at latitude 36.006358 and longitude -83.323622, in Jefferson County, Tennessee.

This permit is issued as a result of the application filed on October 23, 2009, in the office of the Tennessee Division of Water Pollution Control and in conformity with approved plans, specifications and other data submitted to the Department in support of the above application, all of which are filed with and considered as a part of this permit, together with the following named conditions and requirements.

This permit shall become effective on: February 1, 2010

This permit shall expire on: December 30, 2011

Issuance date: December 30, 2009



**Paul E. Davis
Director
Division of Water Pollution Control**

This permit allows the operation of a holding tank/haul system to dispose of domestic wastewater at the above described location. The result of this system is that there is no discharge of wastewater to a surface stream and no contamination of any subsurface waters.

The system must be constructed, maintained and operated in accordance with plans and specifications approved by the Division of Water Pollution Control.

The permittee must provide for wastewater to be pumped from this system on a regular schedule sufficient to ensure that a reasonable margin of safety is provided against the possibility of an overflow. Records of when pumping takes place must be kept at the facility for review by the Division of Water Pollution Control over the entire life of this system. Monthly operation reports will be submitted to Division of Water Pollution Control, Knoxville Environmental Field Office, 3711 Middlebrook Pike, Knoxville, TN 37921, giving pumping dates and volume of waste pumped on each trip. Reports shall also include the liquid level in the tank prior to each pumping, in terms of the volume of capacity remaining. Pumping frequencies should be sufficient to ensure that the tank remains below 3/4 full, in terms of volume capacity, at all times. Reports shall be submitted by the 15th day of the month following data collection.

A representative of the owner or the sewage hauling contractor must be present at all times during the pumping of sewage from this system and must visually monitor the transfer operation to ensure that no spillage occurs.

The owner or the sewage hauling contractor must clean up any spillage of sewage that results from this operation of this system.

It is the owner's responsibility to ensure that the sewage hauling contractor performs all work relative to this system in accordance with this permit and good operating procedures.

Any disposal must be at the Newport Utilities.

Notwithstanding this permit, the permittee shall remain liable for any damages sustained by the State of Tennessee, including but not limited to fish kills and losses of aquatic life and/or wildlife, as a result of the discharge of wastewater to any surface or subsurface waters. Additionally, it shall be the responsibility of the permittee to conduct its wastewater treatment and/or disposal activities in a manner such that public or private health hazards or nuisances will not be created.

This permit is subject, at any time, to review by the Tennessee Department of Environment and Conservation, Division of Water Pollution Control.

Schedule of Compliance

Within thirty (30) days of the availability of public sewers at this site, the use of the holding tank/haul system will be discontinued. The tank will be emptied (with proper disposal of contents), cleaned and removed from the site.

Placement of Signs

The permittee shall place a sign at all approaches to the holding tanks. The sign should be clearly visible to the public. The minimum sign size should be two feet by two feet (2' x 2') with one inch (1") letters. The sign should be made of durable material and have a white background with black letters.

**HOLDING TANKS
SANITARY WASTEWATER
(PERMITTEE'S NAME)
(PERMITTEE'S PHONE NUMBER)
TENNESSEE DIVISION OF WATER
POLLUTION CONTROL
KNOXVILLE ENVIRONMENTAL FIELD
OFFICE
PHONE NUMBER: 1-888-891-8332**

