

STATE OF TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION DIVISION OF WATER RESOURCES

William R. Snodgrass - Tennessee Tower 312 Rosa L. Parks Avenue, 12th Floor Nashville, Tennessee 37243-1102

March 1, 2017

Mr. Tim Releford Tennessee Dickel Distilling Company 1950 Cascade Hollow Road Tullahoma, TN 37388 CERTIFIED MAIL
RETURN RECEIPT REQUESTED
7196 9008 9111 3807 5870

Subject:

NOTICE OF VIOLATION NPDES PERMIT TN0002470 COFFEE COUNTY, TENNESSEE

Dear Mr. Releford,

The Tennessee Division of Water Resources has conducted a Compliance Status Review of the Discharge Monitoring Reports (DMRs) for Tennessee Dickel Distilling Company, (NPDES Permit TN0002470). It has been noted that the facility failed to operate within permit effluent limits at Outfall 002-G for total Residual Chlorine during the monitoring periods of October 2016 and December 2016, as detailed in the attached report.

The Division of Water Resources requires a written explanation for the violations summarized above within 30 days. The explanation must include the precise cause of the violations and the corrective action taken to avoid future violations. Please be aware that failure to comply with your NPDES permit may subject you to enforcement action. Pursuant to T.C.A. §69-3-115, civil penalties may be assessed for each day a violation occurs or continues.

The Division appreciates your efforts to maintain water quality. If you have any comments or questions, please contact Angela Hall at (615) 532-9506.

Sincerely,

Jessica Murphy

Manager, Compliance and Enforcement Unit

EJM:AJH

cc:

DWR – EFO-Columbia DWR – Compliance File

| Effluent Violations | | | | | | | |
|-------------------------------|-----------|-------------------------------------|--------------|---------------------------|-------------------------|--------------|----------------------|
| Monitoring Period End Date | Limit Set | Parameter | SNC Group | Value Type/ Stat. Base | Reported Value/Units | % Exceed. | Limit Value/Units |
| 12/31/2016 | 002-G | 50060 - Chlorine, total residual | 2 | C3 DAILY MX | .07 mg/l | 250% | <=.02 mg/l |
| 10/31/2016 | 002-G | 50060 - Chlorine, total residual | 2 | C3 DAILY MX | .04 mg/l | 100% | <=.02 mg/l |