

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES
William R. Snodgrass - Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243-1102

September 20, 2023
Mr. Dart Kendall
Bethesda Road Subdivision
e-copy: dart@aquagreenutility.com
3350 Galts Road
Acworth, GA 30102

Subject: **Construction Inspection for the Bethesda Road Subdivision**
Aqua Green Utility Inc.
Wastewater Project Number: SOP-20016
County: Williamson

Dear Kendall,

On Tuesday, September 19, 2023, the Division of Water Resources conducted a post construction inspection of the above referenced site. It was determined that the system appears to have been installed in accordance with the plans and specification submitted to the Division.

The project consists of recirculating fixed film trickle filter, UV disinfection and drip dispersal. The system is intended to service a subdivision with a design flow of .0331 MGD.

Fencing was installed and signs were posted according to the regulations.

A copy of the plans showing the exact location of the treatment system, tanks, control building, drip zones, and any additional appurtenances relative to the wastewater treatment system as installed were on site, per the permit requirements. It is recommended that a hard copy of the plans be kept onsite.

If we may be of any assistance, please feel free to contact Mr. Bryan Pope EC at (931) 224-3098 or by E-mail at bryan.pope@tn.gov.

Sincerely,

Bryan Pope

A handwritten signature in blue ink that reads "Bryan Pope EC".

Land-Based Systems Unit
cc: Land-Based System