

PERMIT NUMBER	PERMIT FEATURE TYPE DESCRIPTION	PERMIT FEATURE ID	YEAR	MONTH	DATE	RAINFALL (0.1 inch)	INFLUENT FLOW (MGD)	EFFLUENT FLOW (MGD)	HOURS BYPASSED	CBOD ₅ EFFLUENT (mg/L)	CBOD ₅ EFFLUENT (POUNDS)	Ammonia N EFFLUENT (mg/L)	Ammonia N EFFLUENT (POUNDS)	TSS EFFLUENT (mg/L)	TSS EFFLUENT (POUNDS)	DO EFFLUENT (mg/L)	pH EFFLUENT (S.U.)	Less Than (-) Settlesable Solids EFFLUENT (ml/L)	Less Than (-) E.coli	EFFLUENT E.COLI	Less Than (-) TRC	EFFLUENT TOTAL CHLORINE RESIDUAL (mg/L)	
TN0057878	External Outfall	001	2023	August	1			0.000								8.9	7.7					0.01	
TN0057878	External Outfall	001	2023	August	2			0.001								8.6	7.7	0.1				0.02	
TN0057878	External Outfall	001	2023	August	3			0.001								8.8	7.7					0.02	
TN0057878	External Outfall	001	2023	August	4			0.001								9.0	7.6	0.1				0.02	
TN0057878	External Outfall	001	2023	August	5																		
TN0057878	External Outfall	001	2023	August	6																		
TN0057878	External Outfall	001	2023	August	7			0.000				0.480	0.002	6.0	0.0	7.8	7.7				36.8	0.02	
TN0057878	External Outfall	001	2023	August	8			0.001								7.9	7.6					0.02	
TN0057878	External Outfall	001	2023	August	9			0.000		1.0	0.0					7.8	7.6	0.1				0.01	
TN0057878	External Outfall	001	2023	August	10			0.000								7.7	7.6					0.01	
TN0057878	External Outfall	001	2023	August	11			0.000								7.9	7.4					0.00	
TN0057878	External Outfall	001	2023	August	12																		
TN0057878	External Outfall	001	2023	August	13																		
TN0057878	External Outfall	001	2023	August	14			0.000								7.9	7.7					0.01	
TN0057878	External Outfall	001	2023	August	15			0.000								8.8	7.4					0.01	
TN0057878	External Outfall	001	2023	August	16			0.000								6.8	6.7	0.1				0.02	
TN0057878	External Outfall	001	2023	August	17			0.001								7.8	6.7					0.02	
TN0057878	External Outfall	001	2023	August	18			0.001								6.7	6.5	0.1				0.02	
TN0057878	External Outfall	001	2023	August	19																		
TN0057878	External Outfall	001	2023	August	20											7.2	7.0					0.02	
TN0057878	External Outfall	001	2023	August	21			0.001								7.2	6.7					0.01	
TN0057878	External Outfall	001	2023	August	22			0.000								7.1	7.0					0.00	
TN0057878	External Outfall	001	2023	August	23			0.000								7.2	7.2	0.1				0.00	
TN0057878	External Outfall	001	2023	August	24			0.000								7.0	7.1					0.00	
TN0057878	External Outfall	001	2023	August	25			0.001															
TN0057878	External Outfall	001	2023	August	26																		
TN0057878	External Outfall	001	2023	August	27																		
TN0057878	External Outfall	001	2023	August	28			0.000								7.0	6.4					0.02	
TN0057878	External Outfall	001	2023	August	29			0.000								6.2	6.8					0.02	
TN0057878	External Outfall	001	2023	August	30			0.000								7.1	6.7					0.01	
TN0057878	External Outfall	001	2023	August	31			0.000								6.5	6.4	0.1				0.02	
TOTAL						0.00	0.000	0.010	0.0		0.0		0.002		0.0								
AVERAGE							#DIV/0!	0.000		1.0	0.0	0.480	0.002	6.0	0.0	7.6		0.1			36.8	0.01	
MAXIMUM						0.00	0.000	0.001	0.0	1.0	0.0	0.480	0.002	6.0	0.0	8.0	7.7				36.8	0.02	
MINIMUM							0.000	0.000		1.0	0.0	0.480	0.002	6.0	0.0	6.2	6.4				36.8	0.00	
PERMIT LIMIT DAILY MAX										20.0	0.0	10.000	0.000	45.0	9999.0	3.0	6.0				941.0	0.02	
PERMIT LIMIT MONTHLY WQVAVG										10.0	0.0	5.000	0.000	30.0	0.0	0.0						126.0	0.00

* E. Coli geometric is shown in the Average row

Michael Fort
Signature

Dutch Valley
Elementary School
Plant

3
Grade

4319
Certification #

Anderson
County