

PERMIT NUMBER	PERMIT FEATURE TYPE DESCRIPTION	PERMIT FEATURE ID	YEAR	MONTH	DATE	RAINFALL (0.1 inch)	INFLUENT FLOW (MGD)	EFFLUENT FLOW (MGD)	HOURS BYPASSED	CBOD <sub>5</sub> EFFLUENT (mg/L)	CBOD <sub>5</sub> EFFLUENT (POUNDS)	Ammonia N EFFLUENT (mg/L)	Ammonia N EFFLUENT (POUNDS)	TSS EFFLUENT (mg/L)	TSS EFFLUENT (POUNDS)	DO EFFLUENT (mg/L)	pH EFFLUENT (S. U.)	Less Than (<) Settleable Solids EFFLUENT (ml/L)	Less Than (<) E.coli	EFFLUENT E.COLI	Less Than (<) TRC	EFFLUENT TOTAL CHLORINE RESIDUAL (mg/L)			
TN0057878	External Outfall	001	2024	April	1																				
TN0057878	External Outfall	001	2024	April	2			0.001								8.5	6.8					0.00			
TN0057878	External Outfall	001	2024	April	3			0.001								8.9	7.0	0.2				0.02			
TN0057878	External Outfall	001	2024	April	4			0.001								8.3	7.1					0.01			
TN0057878	External Outfall	001	2024	April	5			0.001		3.0	0.0	0.033	0.000			8.1	7.0	0.1				0.00			
TN0057878	External Outfall	001	2024	April	6																				
TN0057878	External Outfall	001	2024	April	7																				
TN0057878	External Outfall	001	2024	April	8			0.000								8.1	6.8					0.02			
TN0057878	External Outfall	001	2024	April	9			0.000								8.5	7.1					0.02			
TN0057878	External Outfall	001	2024	April	10			0.000								8.5	6.8	0.1				0.02			
TN0057878	External Outfall	001	2024	April	11			0.000								8.9	6.8					0.01			
TN0057878	External Outfall	001	2024	April	12			0.000								8.8	6.3	0.1				0.02			
TN0057878	External Outfall	001	2024	April	13																				
TN0057878	External Outfall	001	2024	April	14																				
TN0057878	External Outfall	001	2024	April	15			0.001								8.7	7.4				67.0	0.02			
TN0057878	External Outfall	001	2024	April	16			0.000								8.6	7.3	0.2				0.02			
TN0057878	External Outfall	001	2024	April	17			0.000							6.0	0.0	8.2	7.3				0.01			
TN0057878	External Outfall	001	2024	April	18			0.000								8.7	7.1					0.01			
TN0057878	External Outfall	001	2024	April	19			0.000								8.3	6.9	0.2				0.00			
TN0057878	External Outfall	001	2024	April	20																				
TN0057878	External Outfall	001	2024	April	21			0.000								8.4	6.7					0.02			
TN0057878	External Outfall	001	2024	April	22			0.000								8.7	6.8					0.00			
TN0057878	External Outfall	001	2024	April	23			0.000								8.7	6.7	0.1				0.01			
TN0057878	External Outfall	001	2024	April	24			0.000								7.9	7.0					0.02			
TN0057878	External Outfall	001	2024	April	25			0.000								8.8	7.1	0.1				0.02			
TN0057878	External Outfall	001	2024	April	26																				
TN0057878	External Outfall	001	2024	April	27																				
TN0057878	External Outfall	001	2024	April	28											8.4	7.5					0.02			
TN0057878	External Outfall	001	2024	April	29			0.001								8.5	7.4	0.1				0.01			
TN0057878	External Outfall	001	2024	April	30			0.001																	
TN0057878	External Outfall	001	2024	April	31			0.007	0.0																
I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.						TOTAL	0.00	0.000	0.007	0.0															
						AVERAGE	3.0	0.0	0.053	0.000	6.0	0.0	8.8						0.1			67.0	0.01		
						MAXIMUM	3.0	0.0	0.053	0.000	6.0	0.0	8.5	7.5	0.2				0.2			67.0	0.02		
						MINIMUM	3.0	0.0	0.053	0.000	6.0	0.0	7.9	6.3	0.1				0.1			67.0	0.00		
						PERMIT LIMIT DAILY MAX	20.0	0.0	10,000	0.000	45.0	9999.0	8.0	1.0					8.0	8.0	1.0			941.0	0.02
						PERMIT LIMIT DAILY MIN																			
						PERMIT LIMIT MONTHLY WQV/VAVG	10.0	0.0	5,000	0.000	30.0	0.0	0.0											126.0	0.00

\*E. Coli geometric is shown in the Average row

Note: April 1st no school, no flow, and no test.

*Michael Faust*  
Signature

Dutch Valley  
Elementary School  
Plant

3

4319

Anderson  
County