



210 SOUTH CHURCH STREET
MOUNTAIN CITY, TENNESSEE 37683
TELEPHONE (423) 727-8005 • FAX (423) 727-2925
www.mountaincitytn.org

May 8, 2024

TDEC
Division of Water Resources
2305 Silverdale Road
Johnson City, TN 37601

Attn: Sandra Vance

The purpose of this letter is to submit the MOR/DMR for The Town of Mountain City WWTP, Permit #TN0024945, for the month of April 2024.

During the month of April, we had the following Violations:


1-E-Coli Daily Maximum
1-CBOD % Removal

The E-COLI violation is suspected to have been caused by an organic overload from a substantial industrial user. Sampling is ongoing with the industry and data is being compiled for further determination.

THE CBOD violation is due to lab operator using too high percentage dilutions for the test resulting in an incompliance with Standard Methods 5210-B-2016. Operator has been reminded and retrained on proper procedures for dilutions of the CBOD test.

If you have any questions, please don't hesitate to call me at 423-727-8005 or Chris Atwood, WWTP Manager at 423-727-6655.

Sincerely,



Jerry Jordan, Mayor

