

NAME OF WATER UTILITY KINGSTON WATER DEPARTMENT
NAME OF WATER TREATMENT PLANT: KINGSTON WATER PLANT
COUNTY ROANE PWSID # 360

TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
Division of Water Supply
COMPREHENSIVE MONTHLY OPERATION REPORT

MONTH OF January YEAR 2024

Main data table with columns: DATE, RAW WATER TREATED - 1,000 GALLONS, FINISHED WATER PUMPED TO SYSTEM - 1,000 GALLONS, TEMPERATURE C, TURBIDITY, CHLORINE RESIDUAL MG/L, ALKALINITY PHENOLPHTHALEIN MG/L, pH, HARDNESS MG/L, PO4 MG/L, H2O2 MG/L, IRON MG/L, MANGANESE MG/L, FLUORIDE MG/L, and CHEMICALS USED (POUNDS PER 24 HOURS, CALCULATED DOSAGE MG/L).

Summary table with columns: CHEMICAL USED, BRAND, ANALYSIS, COST (PER LB, PER MONTH).



I certify that the data provided accurately represents the water quality, quantity, treatment, operational practices, and other activities for the reporting period specified herein.

CERTIFIED OPERATOR

Signature of John M. Poole and PRINT name.

DATE	RAW WATER TREATED 1,000 GALLONS	JAR TEST DATA				COMPLETE APPLICABLE BLANKS EACH MONTH.	FILTER OPERATION DATA						DINSINFECTON AND CT VALUES										MICROBIOLOGICAL EXAMINATION AND SYSTEM PRESSURE					Location of sampling point in distribution system. Must vary within system.									
		COAGULANT MG/L	PH ADJUSTMENT MG/L	PH	NUMBER OF FILTERS USED		FILTER HOURS= COL-54 x HOURS RUN	AVERAGE LENGTH FILTER RUN - HOURS	RATE-OF-FLOW GAUGES WORKING	LOSS-OF-HEAD GAUGES WORKING	TURNIDIMETERS WORKING	BACKWASH RATE gpm/ft2	BACKWASH WATER USED - 1,000 gallons	FIRST DISINFECTON SEQUENCE					SECOND DISINFECTON SEQUENCE					TOTAL CT CALC. INACTIVATION CT REQ RATIO	RAW	PLANT EFFLUENT DISTRIBUTION SYSTEM	FREE CHLORINE MGL AT POINT OF SAMPLING & DISTRIBUTIC SYSTEM		BT Results								
														FREE CHLORINE C END OF SEQUENCE	CONTACT TIME T IN MINUTES	END OF PH SEQUENCE	CT CALCULATED	CT REQUIRED	FREE CHLORINE C END OF SEQUENCE	CONTACT TIME T IN MINUTES	END OF PH SEQUENCE	CT CALCULATED	CT REQUIRED														
47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78						
1	413						2	11.14	5.57	ok	ok	ok	18								2.9	74.4	7.6	215.8	27	7.99	56	0									
2	443					(a) Type of Filters - Gravity (x) gravity	2	11.40	5.70	ok	ok	ok	18								2.9	74.4	7.5	215.8	27	7.99	125	0			2.2	N	1008 Brentwood Way				
3	569					Pressure ()	2	12.76	6.38	ok	ok	ok	18	50							3.0	74.4	7.5	223.2	28	7.97	179	0			2.1	N	1004 north Bridge Close				
4	504					(b) Number of Filters -	2	12.96	6.48	ok	ok	ok	18								3.0	74.4	7.6	223.2	28	7.97	116	0			2	N	1249 Gallaher Rd				
5	545						2	14.60	7.30	ok	ok	ok	18								2.5	74.4	7.6	186.0	28	6.64	131	0			2.3	N	Arowhead @ Old James Ferry				
6	428					(c) Filter Area - Sq Ft. (Each)	174sqft	2	11.00	5.50	ok	ok	ok	18							2.7	74.4	7.7	200.9	27	7.44	166	0			2.2	N	Kingston Hght. Tank				
7	464						2	12.50	6.25	ok	ok	ok	18								2.6	74.4	7.6	193.4	27	7.16	127	0									
8	438					(d) Filter Area - Sq Ft. (Each)	174sqft	2	11.24	5.62	ok	ok	ok	18							2.9	74.4	7.5	215.8	28	7.71	121	0									
9	585						2	15.80	7.90	ok	ok	ok	18	50							2.8	74.4	7.6	208.3	27	7.72	313	0									
10	425					(e) Total Area - Sq Ft. -	348sqft	3	10.80	5.40	ok	ok	ok	18							2.9	74.4	7.5	215.8	28	7.71	309	0									
11	506						2	13.44	6.72	ok	ok	ok	18								2.8	74.4	7.4	208.3	27	7.72	1986	0									
12	416					(f) Filter Rate gpm/ft2	4gpm/ft2	4	10.54	5.27	ok	ok	ok	18							2.9	74.4	7.4	215.8	27	7.99	1733	0			2.3	N	121 Lakewood				
13	426						2	11.34	5.67	ok	ok	ok	18								2.9	74.4	7.4	215.8	27	7.99	1733	0			2.3	N	Waterford across / City Hall				
14	631					(g) Filter Rate gpm/ft2	4gpm/ft2	4	13.70	6.85	ok	ok	ok	18	60						3.2	74.4	7.4	238.1	28	8.50	727	0			2	N	2623 Lawnville Rd				
15	525						2	14.00	7.00	ok	ok	ok	18								3.1	74.4	7.5	230.6	28	8.24	261	0			2.1	N	Bonneyview Tank				
16	476					(h) Total Rated Filter Capacity	700gpm	7	12.10	6.05	ok	ok	ok	18							3.2	74.4	7.5	238.1	37	6.43	326	0			2	N	Kingston Hgts Pump Station				
17	839					GPM -	700gpm	7	19.20	9.60	ok	ok	ok	18							2.9	74.4	7.4	215.8	36	5.99	249	0									
18	778					(i) Ion Exchange Unit Regenerate		2	16.64	8.32	ok	ok	ok	18	51						2.5	74.4	7.5	186.0	35	5.31	411	0									
19	1036					With: Salt ()		2	25.86	12.93	ok	ok	ok	18	29						2.5	74.4	7.6	186.0	36	5.17	866	0									
20	691					KMnO4 ()		2	15.76	7.88	ok	ok	ok	18	50						2.5	74.4	7.4	183.8	36	5.10	770	0									
21	1130					Acid ()		2	28.44	14.22	ok	ok	ok	18	49						2.4	74.4	7.5	181.5	35	5.19	261	0									
22	1419						2	33.64	16.82	ok	ok	ok	18	76							2.6	74.4	7.5	193.4	35	5.53	548	0									
23	1362						2	33.26	16.63	ok	ok	ok	18	50							2.7	74.4	7.5	200.9	36	5.58	770	0									
24	504						2	13.60	6.80	ok	ok	ok	18								3.0	74.4	7.5	223.2	37	6.03	411	0									
25	700						2	17.90	8.95	ok	ok	ok	18								2.9	74.4	7.5	215.8	36	5.99	411	0									
26	1248						2	33.46	16.73	ok	ok	ok	18	40							2.4	74.4	7.5	178.6	35	5.10	613	0									
27	790						2	20.26	10.13	ok	ok	ok	18	40							2.6	74.4	7.5	193.4	36	5.37	816	0									
28	994						2	26.76	13.38	ok	ok	ok	18	40							2.5	74.4	7.5	186.0	36	5.17	579	0									
29	670						2	17.24	8.62	ok	ok	ok	18	40							2.8	74.4	7.4	208.3	36	5.79	980	0									
30	735						2	19.60	9.80	ok	ok	ok	18								2.7	74.4	7.5	200.9	37	5.43	1203	0									
31	688						2	18.88	9.44	ok	ok	ok	18	49							2.8	74.4	7.4	208.3	37	5.63	435	0									
TOTAL	21376							539.8	269.9					674																							
AVE.	690							17.4	8.7					48																				21.5			
MAX.	1419							18.9	9.4					76																					2.2		
MIN.	413							10.5	5.7					29																					2.3		
																																				2.0	

Remarks: _____

FEB 13 2024

TENNESSEE DEPARTMENT OF ENVIRONMENT
DIVISION OF WATER SUPPLY

COMPREHENSIVE MONTHLY OPERATION REPORT
KINGSTON WATER DEPARTMENT

NAME OF WATER UTILITY
NAME OF WATER TREATMENT PLANT

KINGSTON SPRING SUPPLY COUNTY Roane


PWSID 360

MONTH OF January Year 2024

DATE	WATER TREATED	CALCULATED TURBIDITY NTU	CHLORINE			FLUORIDE			ALKALINITY MG/L		pH		HARDNESS MG/L		PO 4		PLATE COUNT			CL2 MG/L			CORROSION CONTROL
			POUNDS OR GALLONS USED	FREE RESIDUAL MG/L	DIST. SYSTEM	POUNDS OR GALLON USED	CALCULATED	DOSAGE MG/L	DISTRIBUTION SYSTEM MG/L	TOTAL RAW	TOTAL FINISHED	RAW	FINISHED	RAW	FINISHED	SPRING	DISTRIBUTION	RAW	FINISHED	DIST. SYSTEM	GRAVITY FEED LINE	SPRING	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1	450	0.86	60.0	3.0	10	0.49	0.48		138		7.4		144.00	0.18	0.17								
2	456	0.83	60.0	3.0	9	0.43	0.46		135		7.2		136.00	0.18	0.18								
3	424	0.89	60.0	3.4	10	0.52	0.48		135		7.2		140.00	0.06	0.14								
4	452	1.07	60.0	3.0	10	0.48	0.47		138		7.3		142.00	0.07	0.17								
5	467	1.01	60.0	3.4	11	0.51	0.54		137		7.3		140.00	0.12	0.16								
6	447	0.89	60.0	3.6	10	0.49	0.48		135		7.3		142.00	0.14	0.11		0.06	0.03		0.011	0.01		
7	455	0.81	60.0	2.8	10	0.48	0.48		137		7.2		142.00	0.12	0.13		0.04	0.03		0.013	0.01		
8	457	1.43	60.0	2.9	10	0.48	0.51		135		7.3		140.00	0.15	0.10								
9	431	0.90	60.0	3.0	10	0.51	0.49		135		7.2		130.00	0.05	0.14								
10	441	0.87	60.0	2.9	9	0.45	0.42		130		7.2		130.00	0.06	0.15								
11	464	0.21	60.0	2.9	10	0.47	0.50		115		10.0		120.00	0.15	0.13								
12	439	4.92	60.0	2.8	10	0.50	0.48		109		9.9		122.00	0.15	0.14								
13	453	4.92	60.0	3.0	10	0.48	0.48		112		6.9		124.00	0.10	0.15		0.02	0.03		0.010	0.01		
14	455	4.13	60.0	3.0	9	0.43	0.43		105		6.9		120.00	0.14	0.13		0.00	0.03		0.013	0.01		
15	460	3.33	60.0	2.7	9	0.43	0.41		105		6.8		110.00	0.06	0.07								
16	474	2.45	60.0	2.3	9	0.41	0.64		110		6.9		120.00	0.06	0.16								
17	463	2.71	60.0	2.8	9	0.42	0.69		108		6.9		110.00	0.05	0.07								
18	419	2.07	60.0	3.0	11	0.57	0.57		107		7.2		112.00	0.14	0.08								
19	447	1.94	60.0	2.8	9	0.44	0.56		110		7.1		124.00	0.10	0.10								
20	452	2.26	60.0	2.5	9	0.43	0.62		113		7.1		126.00	0.18	0.08		0.03	0.02		0.011	0.01		
21	456	1.80	60.0	2.3	10	0.48	0.68		115		7.1		126.00	0.18	0.22		0.03	0.02		0.014	0.01		
22	374	1.31	60.0	2.3	12	0.70	0.63		116		7.1		122.00	0.16	0.15								
23	442	1.49	60.0	2.1	11	0.54	0.55		116		7.2		126.00	0.05	0.06								
24	457	1.28	60.0	2.1	11	0.53	0.51		110		7.3		120.00	0.12	0.16								
25	455	1.38	60.0	2.9	10	0.48	0.55		121		7.1		110.00	0.05	0.08								
26	452	1.38	60.0	2.9	10	0.48	0.72		100		7.1		110.00	0.05	0.08								
27	464	3.83	60.0	2.9	10	0.47	0.62		90		6.9		100.00	0.05	0.06		0.03	0.01		0.022	0.01		
28	483	4.90	60.0	2.7	9	0.41	0.66		100		6.9		110.00	0.09	0.07		0.04	0.02		0.012	0.01		
29	479	4.51	60.0	2.8	9	0.41	0.66		80		7.0		80.00	0.04	0.14								
30	475	4.21	60.0	2.6	9	0.41	0.50		112		7.5		102.00	0.09	0.15								
31	464	3.44	60.0	2.8	9	0.42	0.56		52		7.4		50.00	0.15	0.08								
TOTAL	14007	68.0	1860.0	87.20	304.0	14.76	16.8	0.00	3561.00	0.00	226.5	0.00	3730.00	3.29	3.81	0.00	0.25	0.19	0.00	0.106	0.08	0.00	
AVE.	452	2.19	60.00	2.81	9.81	0.48	0.54	0.00	114.87	0.00	7.31	0.00	120.32	0.11	0.12	0.00	0.03	0.02	0.00	0.013	0.01	0.00	
MAX.	483	4.92	60.00	3.60	12.00	0.70	0.72	0.00	138.00	0.00	9.96	0.00	144.00	0.18	0.22	0.00	0.06	0.03	0.00	0.022	0.01	0.00	
MIN.	374	0.21	60.00	2.10	9.00	0.41	0.41	0.00	52.00	0.00	6.78	0.00	50.00	0.04	0.06	0.00	0.00	0.01	0.00	0.010	0.01	0.00	

REMARKS _____

Certified Operator

 John M. Boole
Signature



BACTERIOLOGICAL EXAMINATION			
DATE	DATE SAMPLE COLLECTED	FREE CHLORINE MG/L AT POINT OF SAMPLING	LOCATION OF SAMPLING POINT FROM DISTRIBUTION SYSTEM
24	25	26	27
1	1-Jan	2.90	# 1 Pump Station
2	2-Jan	2.10	1503 James Ferry Rd
3	3-Jan	3.00	Lakeside Dr.
4	4-Jan	2.80	Ladd Landing Tank
5	5-Jan	2.80	300 W Race St
6	6-Jan	2.40	# 2 Pump Station
7	7-Jan	2.60	614 N. Kentucky St.
8	8-Jan	2.90	Popular Springs Pump Station
9	9-Jan	2.70	900 Waterford Place
10	10-Jan	2.00	Ridgecrest Tank
11	11-Jan	2.50	Kingston Heights Tank
12	12-Jan	2.50	HWY 70 & Gallaher
13	13-Jan	2.90	# 1 Pump Station
14	14-Jan	2.30	# 2 Pump Station
15	15-Jan	2.40	1503 James Ferry Rd
16	16-Jan	2.30	614 N. Kentucky St.
17	17-Jan	2.70	Morrison Hill Tank
18	18-Jan	2.40	308 W. Race Street
19	19-Jan	2.50	Lakeside Dr.
20	20-Jan	2.00	# 2 Sewer Pump Station
21	21-Jan	2.00	HWY 70 & Gallaher
22	22-Jan	2.10	1503 James Ferry Rd
23	23-Jan	2.00	Popular Springs Pump Station
24	24-Jan	2.10	Morrison Hill Tank
25	25-Jan	2.20	Kingwood Tank
26	26-Jan	2.50	935 N Kentucky St -
27	27-Jan	2.50	# 2 Sewer Pump Station
28	28-Jan	2.40	# 1 Pump Station
29	29-Jan	2.60	Ridgecrest Tank
30	30-Jan	2.30	430 Ladd Landing
31	31-Jan	2.60	Ladd landing Pump Station
TOTAL		76.00	
AVE.		2.45	
MAX.		3.00	
MIN.		2.00	



**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES – WATER SUPPLY SECTION
6th Floor, L & C Tower, 401 Church Street
Nashville, Tennessee 37243**

FEB 13 2024

**MONTHLY DISTRIBUTION SYSTEM FLUORIDE SAMPLING SUMMARY
and QUARTERLY CHECK SAMPLE REPORTING**

PUBLIC WATER SYSTEM NAME & ADDRESS	
KINGSTON WATER DEPARTMENT	
900 WATERFORD PLACE	
KINGSTON, TN 37763	
Contact Person:	John M. Poole
PWS ID Number: TN0000360	County: ROANE

	Month ⁽¹⁾	Average for Month mg/L ⁽²⁾	Highest Fluoride Measurement mg/L ⁽³⁾	Lowest Fluoride Measurement mg/L ⁽⁴⁾	Number of Days Fluoride Measured ⁽⁵⁾
1.	January	0.60	0.69	0.48	31
2.	February				
3.	March				
4.	April				
5.	May				
6.	June				
7.	July				
8.	August				
9.	September				
10.	October				
11.	November				
12.	December				

Instructions:

This form is to be completed by all community water systems that add fluoride to their finished water. It may be submitted monthly or quarterly to the Division of Water Supply at the address listed below.

- (1) Enter the month for which the results are being reported.
- (2) Enter the arithmetic average of all distribution system fluoride measurements taken during the month.
- (3) Enter the highest fluoride value measured during the month in the distribution system.
- (4) Enter the lowest fluoride value measured during the month in the distribution system.
- (5) Enter the number of days fluoride samples were taken in the distribution system.
- (6) **Mail form to the above address.** For assistance or questions call 1-888-891-8332

Quarterly Check Samples:

Collection Date	Address	PWS Result (ppm)	Certified Lab	Certified Lab Result (ppm)
			Pace Analytical / ESC Labs	
			Pace Analytical / ESC Labs	
			Pace Analytical / ESC Labs	
			Pace Analytical / ESC Labs	

I certify under penalty of law that this document and all attachments were prepared by me, or under my direction or supervision. The submitted information is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. As specified in Tennessee Code Annotated Section 39-16-702(a)(4), this declaration is made under penalty of perjury.

n.
 Certified Operator: John M. Poole Signature: *John M. Poole* Date: 02/06/24
 Phone: 865-376-7187



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER SUPPLY

DISINFECTANT MONITORING AND MRDL COMPLIANCE REPORT

FEB 13 2024

PWSID #		ENTRY POINT	PUBLIC WATER SYSTEM NAME AND ADDRESS	
0 0 0 0 3 6 0		A	KINGSTON WATER DEPARTMENT	
SAMPLE PERIOD		900 WATERFORD PLACE		
START DATE	END DATE	KINGSTON, TN 37763		
0 1 0 1 2 4	0 1 3 1 2 4			
m m d d y y	m m d d y y			

I. SYSTEMS USING CHLORINE OR CHLORAMINES ⁽¹⁾

A. Distribution System Monitoring

Number of Samples Required ⁽¹⁾	Number of Samples Taken	Lowest Residual Measured (mg/L)	Average Residual Measured (mg/L)	Number of Samples below 0.2 mg/L	% of Samples 0.2 mg/L or higher
0 1 0	0 1 0	2 . 0 0	2 . 3 0	0 0 0	1 0 0 . 0

B. Entry Point Monitoring (For Sub Part H Systems ⁽²⁾ Only)

Number of Days Residual Measurements Required ⁽³⁾	Number of Days Residual Measurements Taken	Type of Monitoring Conducted	Lowest Residual Measured Entering the D.S.	Was the Continuous Chlorine Analyzer out of service more than 5 consecutive days while this facility was in operation?
3 1	3 1	Grab <input checked="" type="checkbox"/> Continuous <input checked="" type="checkbox"/>	2 . 4 0 mg/L	N ("Y" for yes, or "N" for no)

II. SYSTEMS USING CHLORINE DIOXIDE

A. Entry Point Monitoring

Number of Days Residual Measurements Required	Number of Days Residual Measurements Taken	Highest Residual Measured Entering the D.S.	Number of Days Residual Measured > MRDL	Number of Consecutive Days Residual Measured > MRDL
<input type="text"/>	<input type="text"/>	<input type="text"/> . <input type="text"/> <input type="text"/> mg/L	<input type="text"/>	<input type="text"/>

B. Distribution System Monitoring

1. Systems Not Utilizing Disinfection Booster Stations

Date E.P. Sample Exceeded MRDL	Date of Follow-Up Sampling ⁽⁴⁾	Time of First Sample	Time of Second Sample	Time of Third Sample
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
		Result (mg/L)	Result (mg/L)	Result (mg/L)
		<input type="text"/> . <input type="text"/>	<input type="text"/> . <input type="text"/>	<input type="text"/> . <input type="text"/>

2. Systems Utilizing Disinfection Booster Stations

Date E.P. Sample Exceeded MRDL	Date Follow-Up Sampling ⁽⁵⁾	Closest Customer	Average Point	Maximum Residence Time
<input type="text"/>	<input type="text"/>	<input type="text"/> . <input type="text"/>	<input type="text"/> . <input type="text"/>	<input type="text"/> . <input type="text"/>

- Notes:
- (1) Disinfection residuals must be measured at the same frequency and locations for all total coliform samples that are taken. The number of required samples is the total number of routine and repeat total coliform samples taken during the reporting period.
 - (2) Subpart H Systems are public water systems that treat surface water and/or ground water under the direct influence of surface water.
 - (3) Disinfection residuals must be measured continuously for chlorine for systems serving more than 3,330 persons at the entry point to the distribution system each day of operation. Grab sampling may be conducted at the rate specified in the regulations for systems serving less than 3,300.
 - (4) For systems using chlorine dioxide, and not utilizing booster chlorination facilities in the distribution system, if an entry point sample exceeds the MRDL, a three-sample set of measurements must be taken the day after the exceedance at a point closest to the first customer at six-hour intervals. Analysis must be by Ion Chromatography.
 - (5) For systems using chlorine dioxide, and which utilize booster chlorination facilities in the distribution system, if an entry point sample exceeds the MRDL, a three-sample set of measurements must be taken the day after the exceedance at the following locations: 1) a point closest to the first customer, 2) a point reflecting the average residence time, and, 3) a point reflecting the maximum residence time. Analysis must be by Ion Chromatography.

I CERTIFY THAT THE INFORMATION LISTED ON THIS FORM ACCURATELY CORRESPONDS TO THE OPERATION OF THIS FACILITY FOR THE REPORTING PERIOD SPECIFIED HEREIN.

PREPARED BY John M. Poole DATE 02/06/24 APPROVED BY John M. Poole DATE 02/06/24



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
 DIVISION OF WATER RESOURCES, WATER SUPPLY SECTION
 INTERIM ENHANCED SURFACE WATER TREATMENT RULE
 FILTER PERFORMANCE REPORT ⁽¹⁾

FEB 13 2024

PUBLIC WATER SYSTEM NAME AND ADDRESS
 KINGSTON WATER DEPARTMENT

900 WATERFORD PLACE
 KINGSTON, TN 37763

PWSID #						ENTRY POINT	SAMPLE PERIOD						TOTAL HOURS PLANT OPERATED THIS MONTH			LABORATORY ID											
0	0	0	0	3	6	0	A	0	1	0	1	2	4	0	1	3	1	2	4	2	7	0	0	0	3	4	2
REPORTABLE SAMPLES ⁽²⁾						NUMBER OF REPORTABLE SAMPLES LESS THAN OR EQUAL TO THE LOWER NTU STANDARD ⁽³⁾	PERCENT OF REPORTABLE SAMPLES LESS THAN OR EQUAL TO THE LOWER NTU STANDARD						NUMBER OF REPORTABLE SAMPLES EXCEEDING THE UPPER NTU STANDARD ⁽⁴⁾			HIGHEST FINISHED WATER TURBIDITY THIS MONTH											
REQUIRED		TAKEN											(LIST DATES ON BACK)														
0	6	8	0	9	3	0	9	3	1	0	0	0	1	0	0	0	0	0	2	5	2						

Notes:

- (1) This form applies to filtration systems utilizing either a surface water supply or a source that has been designated groundwater under the direct influence of surface water.
- (2) Systems utilizing cartridge filtration must at a minimum, measure turbidity once per day while treating water. Systems required to measure and record finished water turbidity every 4 hours that the plant is in operation, shall report the highest value measured during each 4-hour period. Systems utilizing continuous monitoring turbidimeters shall report the highest recorded value for every 4 hour period.
- (3) NTU standards vary depending on the type of filtration treatment provided, and include a lower limit that must be met in 95% of the reportable samples, and an upper limit that cannot be exceeded without receiving a treatment technique violation. Use the lower NTU standard applicable to this facility for this calculation.
- (4) Indicate the number of reportable samples that exceeded the upper NTU standard. On the back of this form, indicate the dates when a sample exceeded the upper NTU standard, and the date the state was notified of the exceedance.

Did this facility meet the CT requirements for each day it was in operation?	Y or N	B. FOR ANY FILTER AT THIS FACILITY ⁽⁵⁾											
	Y	Were any 2 consecutive filter effluent measurements taken 15 minutes apart:											
A. FOR ALL FILTERS AT THIS FACILITY	Y or N	Y or N	Filter Numbers (maximum of four filters)										
1. Was turbidity monitored continuously and the results recorded for each filter effluent line?	Y	1. Greater than 0.5 NTU after the first 4 hours of operation?	N	0	1	0	2						
2. If the answer to question number 1 is no, was grab sampling conducted for every 4 hours the continuous monitor was out of service?	N	2. Greater than 1.0 NTU?	N	0	1	0	2						
3. If the answer to question number 2 is yes, was grab sampling conducted for more than 5 consecutive days on any individual filter?	N	3. Greater than 1.0 NTU in each of 3 consecutive months?	N	0	1	0	2						
		4. Greater than 2.0 NTU in two consecutive months?	N	0	1	0	2						

Note:

(5) If this facility answered "Yes" to any question listed in Section B. above, then the system must submit a "Monthly Turbidity Exceedance Report" (CN-1196) for the individual filter that met at least one of the conditions listed.

I certify under penalty of law that this document and all attachments were prepared by me, or under my direction or supervision. The submitted information is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. As specified in Tennessee Code Annotated Section 39-16-702(a)(4), this declaration is made under penalty of perjury.

PREPARED BY: John M. Poole DATE: 02/06/24 PHONE: (865) 376-7187 APPROVED BY: John M. Poole DATE: 02/06/24 PHONE: (865) 376-7187



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER SUPPLY

DISINFECTANT MONITORING AND MRDL COMPLIANCE REPORT FEB 13 2024

PWSID # 0000360
ENTRY POINT B
SAMPLE PERIOD START DATE 010124 END DATE 013124

PUBLIC WATER SYSTEM NAME AND ADDRESS
KINGSTON WATER DPT. SPRING SUPPLY
900 WATERFORD PLACE
KINGSTON, TN 37763

I. SYSTEMS USING CHLORINE OR CHLORAMINES (1)

A. Distribution System Monitoring

Number of Samples Required (1) 010
Number of Samples Taken 010
Lowest Residual Measured (mg/L) 2.00
Average Residual Measured (mg/L) 2.30
Number of Samples below 0.2 mg/L 000
% of Samples 0.2 mg/L or higher 100.0

B. Entry Point Monitoring (For Sub Part H Systems (2) Only)

Number of Days Residual Measurements Required (3) 31
Type of Monitoring Conducted Grab [X] Continuous [X]
Lowest Residual Measured Entering the D.S. 2.10 mg/L
Was the Continuous Chlorine Analyzer out of service more than 5 consecutive days while this facility was in operation? [N] ("Y" for yes, or "N" for no)

II. SYSTEMS USING CHLORINE DIOXIDE

A. Entry Point Monitoring

Number of Days Residual Measurements Required [] Taken []
Highest Residual Measured Entering the D.S. [] mg/L
Number of Days Residual Measured > MRDL []
Number of Consecutive Days Residual Measured > MRDL []

B. Distribution System Monitoring

1. Systems Not Utilizing Disinfection Booster Stations

Date E.P. Sample Exceeded MRDL []
Date of Follow-Up Sampling (4) []
Time of First Sample [] Result (mg/L) []
Time of Second Sample [] Result (mg/L) []
Time of Third Sample [] Result (mg/L) []

2. Systems Utilizing Disinfection Booster Stations

Date E.P. Sample Exceeded MRDL []
Date Follow-Up Sampling (5) []
Closest Customer []
Sample Results (mg/L) at Average Point [] Maximum Residence Time []

Notes:

- (1) Disinfection residuals must be measured at the same frequency and locations for all total coliform samples that are taken.
(2) Subpart H Systems are public water systems that treat surface water and/or ground water under the direct influence of surface water.
(3) Disinfection residuals must be measured continuously for chlorine for systems serving more than 3,330 persons at the entry point to the distribution system each day of operation.
(4) For systems using chlorine dioxide, and not utilizing booster chlorination facilities in the distribution system, if an entry point sample exceeds the MRDL, a three-sample set of measurements must be taken the day after the exceedance at a point closest to the first customer at six-hour intervals.
(5) For systems using chlorine dioxide, and which utilize booster chlorination facilities in the distribution system, if an entry point sample exceeds the MRDL, a three-sample set of measurements must be taken the day after the exceedance at the following locations: 1) a point closest to the first customer, 2) a point reflecting the average residence time, and, 3) a point reflecting the maximum residence time.

I CERTIFY THAT THE INFORMATION LISTED ON THIS FORM ACCURATELY CORRESPONDS TO THE OPERATION OF THIS FACILITY FOR THE REPORTING PERIOD SPECIFIED HEREIN.

PREPARED BY John M. Poole DATE 02/06/24 APPROVED BY John M. Poole DATE 02/06/24



**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER SUPPLY
L & C Tower, 6th Floor
401 Church Street
Nashville, Tennessee 37243**

FEB 13 2024

MONTHLY MICROBIOLOGICAL and DISINFECTANT MONITORING REPORT

Public Water System Name <u>KINGSTON WATER DEPARTMENT</u>	Phone: <u>(865) 376-7187</u>
Address <u>900 WATERFORD PLACE, KINGSTON, TN 37763</u>	County: <u>ROANE</u>

Bacteriological Monitoring ⁽¹⁾

PWSID	Contaminant ID	Analysis Method	Sample Period Begin	End
0 0 0 0 3 6 0	3 1 0 0	9 2 2 3	0 1 0 1 2 4	0 1 3 1 2 4
Total Number Of Routine Distribution Samples Analyzed	Total Number Of Positive Samples Analyzed ⁽²⁾	Total Number Of Repeat Samples Analyzed ⁽²⁾	Laboratory ID	Laboratory Name
0 1 0	0 0 0	0 0 0	0 3 1 2 1	<u>KINGSTON WTP</u> <u>1318 S.KENTUCKY ST</u> <u>KINGSTON, TN 37763</u>
	Date of First Sample		Date of Last Sample	
	0 1 2 3 2 4		0 1 2 9 2 4	

Disinfectant Residual Monitoring ⁽³⁾

Lowest Residual Measured (mg/L)	Average Residual Measured (mg/L)	Number of Samples below 0.2 mg/L	% of Samples 0.2 mg/L or higher
2 . 0 0	2 . 3 0	0 0 0	1 0 0 . 0

Notes

- (1) This form is to be submitted for systems reporting 10 or more bacteriological compliance samples during the reporting period.
- (2) All positive and repeat samples must be reported on Form CN-0800, Bacteriological Analysis Detail.
- (3) Systems supplying chlorinated water must monitor disinfectant residuals at the same locations and frequencies as total coliform sampling is required.

Administrative Information

I certify the information listed on this form accurately corresponds to the operation of this facility for the reporting period specified herein.

Responsible Official: John M. Poole Phone: (865) 376-7187
 Program Contact: John M. Poole Phone: (865) 376-7187
 Technical Contact: John M. Poole Phone: (865) 376-7187

Return to: Tennessee Division of Water Supply, 6th Floor, L & C Tower, 401 Church Street, Nashville TN, 37243