



DIVISION OF LABORATORY SERVICES

OCT 22 2021

Richard Steece, PhD.(ABMM), Director
Nashville Central Laboratory
Nashville, TN 37216
615-262-6300

George J Dizikes, PhD., HCLD/CC(ABB), Director
Knoxville Regional Laboratory
Knoxville, TN 37920
865-549-5201

Print Date: 10/13/2021

Final Report

Page 1 of 1

Accession #: K2110047

Accession Number: K2110047-01

Sample Collector: Ned Jones

Location Code:

Phone: 865-475-3063

Sample Location: Well House

Repeat Sample Location:

Water System: Black Oak Marina Inc

Reason for retest:

Address: 2511 Black Oak Road
Jefferson City, TN 37760

County: Jefferson - 45

EFO: Knoxville EFO

PWSID Number: 4794

Chlorine Residual: 3.0

Sample Source: Drinking Water

Date/Time Collected: 10/11/2021 15:00

Sample Type: (D) Distribution

Date Received: 10/12/2021

TEST: Coliforms P-A

METHOD: 9223-B

PERFORMING LAB: Knoxville Regional Laboratory

ANALYTE	RESULT	UNITS	Qual	ANALYZED BY	DATE
Total Coliform	Absent			Jeff Smith	10/13/2021
Escherichia coli	Absent			Jeff Smith	10/13/2021

System Administrator
Black Oak Marina Inc
2511 Black Oak Road
Jefferson City, TN 37760