



**CITY OF ALCOA**

## WATER QUALITY REPORT 2023

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agricultural, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### INFORMATION ON LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Alcoa is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### THINK BEFORE YOU FLUSH

Flushing unused or expired medicines can be harmful to your drinking water. Properly disposing of unused or expired medication helps protect you and the environment. Keep medications out of Tennessee's waterways by disposing in one of our permanent pharmaceutical take-back bins. In Blount County, medications may be disposed of at the:  
Blount County Justice Center  
940 East Lamar Alexander Pkwy  
Maryville, TN 37804

As shown in the table, the Alcoa Water system had no violations during **2022**, meeting or exceeding all Federal and State requirements. The maximum contaminant levels (MCL's) are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink two liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Public participation in decisions that may affect the quality of our water is welcomed at the Alcoa City Commission meetings, held on the second Tuesday of each month at 7:00 p.m. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. If you have any questions or need additional copies of this report please contact Tyrel Emory, Alcoa Water Plant Supervisor, at 865-380-4921.

### IMPORTANT PHONE NUMBERS

New Service.....865-380-4700  
**Water Trouble or Leaks**

- 8:00 a.m. – 4:30 p.m. ....865-380-4800  
After Hours and Weekends..... 865-380-4921  
Questions About a Bill .....865-380-4700  
Alcoa Water Plant.....865-380-4921

### FREQUENTLY ASKED QUESTIONS

#### Is fluoride in my drinking water?

Yes, trace amounts of fluoride occur naturally in water. The City of Alcoa adjusts this to the level recommended by the American Dental Association and the Center for Disease Control and Prevention for optimal dental health. Numerous studies have shown that fluoridated water will aid in the prevention of tooth decay. More information may be found at [www.ada.org](http://www.ada.org) and [www.cdc.gov](http://www.cdc.gov).

The City of Alcoa routinely monitors for contaminants in your drinking water as required by Federal and State laws. Unless noted otherwise, the following table shows the results of our monitoring for the period of **January 1 to December 31, 2022**. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions and comparisons:

**Below Detection Limit (BDL)** - Laboratory analysis indicates that the contaminant is not present.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - One part per million; equivalent to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/l)** - One part per billion; equivalent to one minute in 2,000 years, or a single penny in \$10,000,000.

**Nephelometric Turbidity Unit (NTU)** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Revised Total Coliform Rule (RTCR)** - This rule went into effect on April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>						
Total Coliform Bacteria (RTCR)	No	1	Presence or Absence	0	TT Trigger	Naturally present in the environment.
E. coli/Bacteria	No	0	Presence or Absence	0	See Footnote 1	Human and animal fecal waste.
Turbidity	No	Level Detected 0.05 Range 0.02—0.05 100% 2	NTU	N/A	TT - ≤ 0.3 NTU in 95% of monthly measurements	Soil runoff.
<b>Inorganic Contaminants</b>						
Lead <sup>2</sup>	No	Level Detected 3.45 Sample Year 2020	ppb	0	AL = 15	Corrosion of household plumbing systems; erosion of natural deposits.
Copper <sup>3</sup>	No	Level Detected 0.128 Sample Year 2020	ppm	13	AL = 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Fluoride	No	Level Detected 0.27 Range 0.00—0.57	ppm	4	4	Water additive, which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories.
Nitrate (as Nitrogen)	No	Level Detected 0.37	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Sodium	No	4.54	ppm	None	None	Erosion of natural deposits.
<b>Disinfectants</b>						
Chlorine	No	Level Detected 1.96 Range 0.84—2.55	ppm	MRDLG = 4	MRDL = 4	Water additive used to control microbes
<b>Organic Contaminants</b>						
Halacetic Acids <sup>4</sup> (HAA5)	No	Highest LLRAA 32 Range 8—48	ppb	0	60	By-product of drinking water chlorination.
Total Trihalomethanes <sup>4</sup> (TTHM)	No	Highest LLRAA 36 Range 10—69	ppb	0	80	By-product of drinking water chlorination.

**1:** E. coli: A system is in compliance with the MCL for E. coli for samples unless any of the conditions identified in parts 1 through 4 occur.

1. The system has an E. coli-positive repeat sample following a total coliform positive routine sample.
2. The system has a total coliform positive repeat sample following an E. coli-positive routine sample.
3. The system fails to take all required repeat samples following an E. coli-positive routine sample.
4. The system fails to test for E. coli when any repeat sample tests positive for total coliform.

**2:** We met the Treatment Technique for Turbidity. 100% of all samples were less than 0.3 NTU. Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

**3:** 1 out of 30 sampling sites exceeded the Lead action level and 0 sites exceeded the Copper action level.

**4:** HAA<sub>5</sub> and TTHMs are the highest Locational Running Annual Average (LRRAA) for all quarters of 2022.