



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION

Division of Water Resources

William R. Snodgrass Tennessee Tower, 312 Rosa L. Parks Ave., 11th Floor, Nashville, TN 37243
1-888-891-8332 (TDEC)

Notice of Intent (NOI) - General Permit for Dischargers from Water Treatment Plants

Type of application (NOI): New Reissuance Modification

(If this NOI is Reissuance or Modification provide the existing permit tracking number: TNR05_____)

Facility Name: Clifton Water System		County: Wayne	
Street Address or Location: 312 W. Water St Clifton, TN 38425		Latitude: (DD.DDD)	35.386
		Longitude: (-DD.DDD)	-87.999
Attach a copy of a topo map, a city map, or a county map, identifying the location of this facility and each outfall			<input checked="" type="checkbox"/> Map Attached

Owner or Operator: (the person or legal entity which controls facility's operation; this may or may not be the same as the facility name or the official contact name):
Austin Clark

1	Official Contact Person Name: (individual responsible for a facility) Austin Clark	Title or Position: Public Works Director		
	Mailing Address: PO Box 192	City: Clifton	State: TN	Zip: 38425
	Phone: () 931-213-1057	E-mail: austinc@cityofclifton.com		

2	Local Contact Person Name: (if appropriate, write "same as #1") Paula Skelton	Title or Position: Operator in Charge		
	Facility Address: (may or may not be the same as street address) 312 W Water St	Facility City: Clifton	State: TN TN	Zip: 38425
	Phone: () 931-628-9067	E-mail:		

Write in the box (to the right) or circle the number (above) to indicate where to send correspondence:

1

PROCESS DESCRIPTION (Reply on a separate page, if necessary)

Name of surface waters receiving the discharge: (and the mileage point, if available) Tennessee River- Mile 157
A description of the source of the raw water; if surface water is used, include the distance the plant is located from the intake point; if the source is groundwater, include the number and depth of wells. Tennessee River-Intake distance from WTP is 300'

Submit the original completed and signed form to the above address or a scanned PDF copy to Water.Permits@tn.gov



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION

Division of Water Resources

William R. Snodgrass Tennessee Tower, 312 Rosa L. Parks Ave., 11th Floor, Nashville, TN 37243
1-888-891-8332 (TDEC)

Notice of Intent (NOI) - General Permit for Dischargers from Water Treatment Plants

A description of the plant, i.e. iron removal, manganese and/or turbidity removal, and a list of any additives used in the water treatment process, such as coagulant, oxidizing enhancers, etc.

Turbidity

Design capacity of treatment plant in millions of gallons per day (MGD): 0.9

Number and volume of sedimentation basins: 1-70K

Average flow of finished water production in MGD over 12 months prior to submission of the NOI: 135mg

Filter backwashing. Number of filters backwashed: 3 Frequency for each filter: 14 times per week. Amount of water used to backwash: 11,000 for each filter. Frequency sedimentation basin is washed out: 2 times per year. Amount of water used to wash out the largest sedimentation basin: 0 gallons. Describe type of treatment provided for backwash and sedimentation basin washwaters and the design capacity of the treatment system:

WWTP

Water is released from the backwash settling basin 341 times per week for 0.25 hours per release and a volume of 1436 gallons per release. For existing facility, give averages from last 12 months of operation. For new facilities, indicate "not available." Describe more fully, if necessary.

n/a

A description of how sludge from the settling processes are disposed, for example, landfill, land applied, etc. landfill

CERTIFICATION AND SIGNATURE

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. As specified in Tennessee Code Annotated Section 39-16-702(a)(4), this declaration is made under penalty of perjury.

Austin Clark

Printed Name

Public Works Director

Official Title

Signature

06/03/2020

Date

STATE USE ONLY

Received Date	Domestic Water Supply Use	Protective for Lead Conc.	Tracking No.	EFO
Unavailable Conditions	Exceptional TN Waters	T & E Aquatic Fauna	NOC Date	Reviewer

