

The Water Commission

Telephone 638-3148

Laura White, Superintendent

P.O. Box 368

Greeneville, Tennessee 37744-0368

RECEIVED

SEP 12 2012

**JOHNSON CITY ENVIRONMENTAL
FIELD OFFICE**

September 7, 2012

Bryan B. Carter

Environmental Protection Specialist

2305 Silverdale Road


Johnson City, TN 37601

RE: Oak Grove Church sewer line

The Greeneville Water Commission was made aware of a sewer problem at Oak Grove Church and Old Tusculum Road during the week of August 25th, 2012. Crews from the GWC jetted the line and were unable to get through. It was determined that the 6" PVC line from the church had separated. When the line was dug up it was discovered that there was water pooled up behind a garage on Old Tusculum Road. The separated line was repaired and dirt was brought in and some wood and trash were hauled off for the resident. I was unaware that the property owner still was unsatisfied. We will do what we need to do for the customer.

If you have any questions concerning this overflow, do not hesitate to call me at 423-638-3148

Sincerely,



Laura White, Superintendent

Greeneville Water Commission