

PERMIT NUMBER	PERMIT FEATURE TYPE DESCRIPTION	PERMIT FEATURE ID	YEAR	MONTH	DATE	RAINFALL (0.1 inch)	INFLUENT FLOW (MGD)	EFFLUENT FLOW (MGD)	HOURS BYPASSED	CBOD <sub>5</sub> EFFLUENT (mg/L)	CBOD <sub>5</sub> EFFLUENT (POUNDS)	Ammonia N EFFLUENT (mg/L)	Ammonia N EFFLUENT (POUNDS)	TSS EFFLUENT (mg/L)	TSS EFFLUENT (POUNDS)	DO EFFLUENT (mg/L)	pH EFFLUENT (S.U.)	Less Than (-) Settleable Solids EFFLUENT (m/L)	Less Than (-) E.coli	EFFLUENT E.COLI	Less Than (-) TRC	EFFLUENT TOTAL CHLORINE RESIDUAL (mg/L)	
																							TOTAL
TN0057878	External Outfall	001	2023	October	1			0.00															
TN0057878	External Outfall	001	2023	October	2			0.00															
TN0057878	External Outfall	001	2023	October	3			0.00															
TN0057878	External Outfall	001	2023	October	4			0.00															
TN0057878	External Outfall	001	2023	October	5			0.00															
TN0057878	External Outfall	001	2023	October	6			0.00															
TN0057878	External Outfall	001	2023	October	7			0.00															
TN0057878	External Outfall	001	2023	October	8			0.00															
TN0057878	External Outfall	001	2023	October	9			0.00															
TN0057878	External Outfall	001	2023	October	10			0.00															
TN0057878	External Outfall	001	2023	October	11			0.00															
TN0057878	External Outfall	001	2023	October	12			0.00															
TN0057878	External Outfall	001	2023	October	13			0.00															
TN0057878	External Outfall	001	2023	October	14																		
TN0057878	External Outfall	001	2023	October	15																		
TN0057878	External Outfall	001	2023	October	16			0.00															
TN0057878	External Outfall	001	2023	October	17			0.00															
TN0057878	External Outfall	001	2023	October	18			0.00		2.0	0.0	0.348	0.000										
TN0057878	External Outfall	001	2023	October	19			0.00															
TN0057878	External Outfall	001	2023	October	20			0.00															
TN0057878	External Outfall	001	2023	October	21																		
TN0057878	External Outfall	001	2023	October	22																		
TN0057878	External Outfall	001	2023	October	23			0.00															
TN0057878	External Outfall	001	2023	October	24			0.00															
TN0057878	External Outfall	001	2023	October	25			0.00															
TN0057878	External Outfall	001	2023	October	26			0.00															
TN0057878	External Outfall	001	2023	October	27			0.00															
TN0057878	External Outfall	001	2023	October	28			0.00															
TN0057878	External Outfall	001	2023	October	29			0.00															
TN0057878	External Outfall	001	2023	October	30			0.00															
TN0057878	External Outfall	001	2023	October	31			0.00															
						TOTAL	0.00	0.000	0.02	0.0	0.0												
						AVERAGE	0.00	0.000	0.000	2.0	0.0	0.348	0.000	2.0	0.0	8.0		0.1			35.5	0.01	
						MAXIMUM	0.00	0.000	0.0	2.0	0.0	0.348	0.000	2.0	0.0	9.1	7.3	0.2		35.5	0.02		
						MINIMUM	0.000	0.000		2.0	0.0	0.348	0.000	2.0	0.0	7.9	6.2	0.1		35.5	0.00		
						PERMIT LIMIT DAILY MAX				20.0	0.0	10.000	0.000	45.0	9999.0		9.0	1.0		941.0	0.02		
						PERMIT LIMIT MONTHLY WQV AVG				10.0	0.0	5.000	0.000	30.0	0.0	0.0				118.0	0.00		

E. Coli question is shown in the Average row

*Michael Faust*  
Signature

Dutch Valley  
Elementary School  
Plant

3

4319

Anderson  
County