



**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES**

William R. Snodgrass - Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243-1102

Tracking No. TNG830264

Notice of Coverage (NOC) under the General NPDES Permit for
UNDERGROUND STORAGE TANK (UST) REMEDIATION

Under authority of the Tennessee Water Quality Control Act of 1977 (T.C.A. 69-3-101 et seq.) and the delegation of authority from the United States Environmental Protection Agency under the Federal Water Pollution Control Act, as amended by the Clean Water Act of 1977 (33 U.S.C. 1251, et seq.) the following operator is authorized to discharge in accordance with effluent limitations, monitoring requirements and other conditions set forth in the UST general permit.

Permittee Name:	ATC Group Services, LLC - Patterson, TDEC Facility ID# 7-270125
is authorized to discharge:	treated groundwater associated with UST remediation
from the facility located at:	335 Alexander Street, BRADFORD, TN, Gibson County
Latitude and longitude:	36.070873, -88.811425
to waters of the state:	unnamed tributary to South Fork Obion River from Outfall 001
Issuance date:	11/22/2023
Effective date:	12/01/2023
Expiration date:	09/30/2028

General UST permit information and overview can be found [here](#).

CN-0759

RDA 2366

Print

From: [Vojin Janjic](#)
To: Kevin.OToole@oneatlas.com
Cc: jewel.cox@oneatlas.com
Subject: TNG830264 - Notice of Coverage (NOC) under UST General NPDES Permit
Date: Wednesday, November 22, 2023 3:11:00 PM
Attachments: [DWR-TNG830264-Notice of Coverage \(NOC\)-20231122-2366.pdf](#)

The Division of Water Resources received from your company a Notice of Intent (NOI) to be covered under the General NPDES Permit for Discharges of Treated Groundwater Associated with Underground Storage Tank Remediation. **We have recorded your facility's information and are hereby notifying you that your facility is covered under this general NPDES permit.**

Attached is a Notice of Coverage (NOC) with the permit tracking number [TNG830264](#), facility's name and address, receiving stream information and other site-specific information that applies to your facility. In order to get a copy of the UST general permit we ask you to visit TDEC's [Dataviewer](#). We will provide you with a printed copy of the UST general permit **only** upon your request.

Description: External Outfall, Number: 001, Monitoring: Effluent Gross, Season: All Year							
Code	Parameter	Qualifier	Value	Unit	Sample Type	Monitoring Frequency	Statistical Base
00400	pH	>=	6.5	SU	Grab	Quarterly	Daily Minimum
00400	pH	<=	9	SU	Grab	Quarterly	Daily Maximum
00530	Total Suspended Solids (TSS)	<=	40	mg/L	Grab	Quarterly	Daily Maximum
01051	Lead, total (as Pb)	<=	.45	mg/L	Grab	Quarterly	Daily Maximum
34010	Toluene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum
34030	Benzene	<=	.005	mg/L	Grab	Quarterly	Daily Maximum
34371	Ethylbenzene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum
45613	Floating solids or visible foam-visual	Report	-	Y=1;N=0	Visual	Quarterly	Value
50050	Flow	Report	-	MGD	Instantaneous	Quarterly	Daily Maximum
81551	Xylene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum

At our [UST website](#), you will find links to this general permit and the permit rationale, notice of determination, guidance documents, and links to relevant web sites. If you do not have access to the web, or have other questions, please contact Jackson [Environmental Field Office](#), call us at 1-888-891-TDEC or contact us by E-mail at Water.Permits@tn.gov.

Thank you for your time and assistance.

Sincerely,
 Division of Water Resources