

### WTP NPDES Compliance Evaluation Inspection

Date: 07/08/2020 NPDES: TN0080969

---

Facility: Jamestown Water Treatment Plant

---

Address: 4757 Round Mountain Road

---

City: Jamestown State: TN Zip: 38556

---

Contact: Brian Ramsey Title: Certified Operator

---

Phone 1: (931)879- 7578 Phone 2:

---

**I. Permit Verification**

Yes	No	Inspection Observation to Verify Information Contained in Permit
✓		1. Current Copy of Permit on-Site?
✓		2. Correct Name and Mailing Address
✓		3. Type of Facility
✓		4. Facility is as Described in Permit
✓		5. State has been notified of new, different increased discharges, if any
✓		6. Number and Location of Discharge Points as Described in Permit
✓		7. Name and Location of Receiving Waters Correct
✓		8. All Discharges Permitted

**II. Recordkeeping and Reporting Evaluation**

Yes	No	Records and Reports Maintained as Required By Permit
✓		1. All Information available, complete, and current
✓		2. Information retained for 3 + years
✓		3. Sampling and Analysis Data are Adequate and Include:

✓		a. Dates, times, location of sampling
✓		b. Initials of Individual Performing Sampling
✓		c. Approved Methods
✓		d. Results of Analyses and Calibration
✓		e. Dates and Time of Analysis
✓		f. Initials of Person Performing Analysis
✓		4. O & M Manual
✓		5. As-built & State Approved Plans and Specifications

Yes	No	DMR Completion Meets the Self-Monitoring Reporting Requirements
✓		1. Analytical Bench Sheets Consistent with the Dates on the DMR
✓		2. All data that is Collected is Summarized on the DMR
✓		3. Number of Exceedences Column Is Completed Correctly

**III. Facility Site Review Checklist**

Yes	No	Treatment Facility Properly Operated and Maintained
✓		1. Standby Power or Other Equivalent Is Provided
✓	✓	2. Alarm System for Power and/or Equipment Is Provided
		a. During Power Failures, have you experienced any problems
	✓	b. Are there untreated bypass discharges during power failures
	✓	3. Sludge Disposal Procedures are Appropriate
	✓	a. Disposal of Sludge According to Federal, State, and Local Regulations
	✓	b. Disposal Sites Approved by State
	✓	4. Sufficient Sludge is Disposed of to Maintain Treatment Integrity
		If Not, Why
	✓	5. Preventative Maintenance Schedules Established and Performed
	✓	6. O & M Adequate
	✓	7. Consulting Engineer on Retainer

**IV. Flow Measurement Checklist**

Yes	No	Flow Measurements Meeting Requirements and Intent of Permit
✓		1. Outfall Inspection by Operator
		Frequency: weekly
✓		2. Effluent Flow Calculated Using Effluent Flow
		If Not, Explain

**V. Laboratory Quality Assurance Checklist**

Yes	No	Laboratory Requirements Meet the Requirements of the Permit
	✓	1. Are Parameters Other Than Those Listed on the Permit Analyzed For
		If so, What:
✓		2. Laboratory Quality Assurance Manual Present
✓		3. EPA Approved Analytical Testing Procedures are Used

✓		4. Laboratory Instruments Calibrated and Maintained
✓		5. Quality Control Procedures In Place
	✓	6. Duplicate Samples Analyzed Frequency:
	✓	7. Spiked Samples Analyzed Frequency:
✓		8. Commercial Laboratory Used Name: PACE Analytical Address: 12065 Lebanon Rd City/State: Mt. Juliet, TN Zipcode: 37122 Phone: (615)758-5858 Contact: Rodney Shinbaum
✓		9. Results of Last DMR/QA Test

### VI. Laboratory Checklist

		1. Chlorine Residual (EPA Approved Minimum Detection Level, 0.05 mg/l)
		a. Amperometric Titration
		b. Starch Endpoint
✓		c. Colormetric
✓		d. Meters Standardized Before Each Day's Use
✓		e. Samples Analyzed Within 15 Minutes of Sample Collection
✓		f. Samples Analyzed for Total Chlorine, not Free
✓		g. Reagents In date
✓		2. Settleable Solids Jamestown WWTP
		a. Samples Thoroughly Shaken
		b. Cobwebs In Imhoff Cone
		c. Correct Procedure (Mix, Cone, 45 Min, Slowly Stir At/Near Top Perimeter of Cone for 15 Min., Read Mark)
✓		3. Total Suspended Solids Jamestown WWTP
		a. Proper Equipment (Vacuum, Filter Holding Mechanism, Drying Oven, etc.)
		b. Proper Filters (Gelman A/E or Approved by Standard Methods)
		c. Balance checked with Standard Weights
		d. Temperature In Drying Oven 103-105°C
		4. pH
✓		a. Equipment Can Be Calibrated at Two Points
✓		b. Bracketing of pH Samples (7 and 4, or 7 and 10)
✓		c. Probe is Temperature Compensating
✓		d. Probe Stored In Manufacturers Recommended Solution
✓		e. Sample Analyzed Within 15 Min. of Collection
✓		g. Buffers and storage solutions In date
		5. Iron Storage
		a. P, FP, or G
✓		b. HNO <sub>3</sub> to pH <2
		6. Aluminum Storage

✓	a. P, FP, or G
	b. HNO <sub>3</sub> to pH <2

\* P is for polyurethane, FP is for fluoropolymer, G is for glass

**VII.**

Yes	No	Permittee Meets the Requirements of the Permit
✓		1. Sampling Locations are as per Permit
✓		2. Sampling and Analytical Constituents and Parameters are as per Permit
✓		3. Sampling and Analytical Frequency is as per Permit
✓		4. Sampling Method is as per Permit
✓		5. Sample Collection Procedures Adequate ;
✓		b. Proper Preservation Technique Used
✓		c. Containers and sample holding times are correct (40CFR 136.3)
✓		6. Are samples collected and analyzed more often than required in Permit