


**Town of Baileyton W.W.T.P.**  
**6530 Horton Highway**  
**Greeneville, TN 37745**  
**Phone #(423) 234-6911**  
**Fax # (423) 234-5442**



September 15, 2020

To; Sandra K. Vance

The Town of Baileyton had a dry weather release at 6340 Horton Highway. We lost around 250 gallons of sewage on the ground.

The cause of the release was due to old rusty piping in an old residential pump station. The station was installed around 1988-1989. We installed new piping in the pump station and did the necessary clean up and spread lime over the affected area. We are planning on replacing the old pump station with a new pump station in the future.

The spilled sewage did not enter the drainage ditch that is on the property.

If you have any further questions. Please feel free to contact me at (423)-234-0991 or (423)-620-8208.

Sincerely

A handwritten signature in cursive script that reads "Danny P. Neely".

Danny P. Neely