



NOTICE OF COVERAGE
General NPDES Permit for Discharges of Filter Backwash and
Sedimentation Basin Washwater from Water Treatment Plants
Tracking Number TN0075884

issued on October 07, 2020 by

STATE OF TENNESSEE
 DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES

William R. Snodgrass - Tennessee Tower
 312 Rosa L. Parks Avenue, 11th Floor
 Nashville, Tennessee 37243-1102

Under authority of the Tennessee Water Quality Control Act of 1977 (T.C.A. 69-3-101 et seq.) and the delegation of authority from the United States Environmental Protection Agency under the Federal Water Pollution Control Act, as amended by the Clean Water Act of 1977 (33 U.S.C. 1251, et seq.):

Discharger: **Bristol/Bluff City Utility District WTP**

is authorized to discharge **filter backwash and sedimentation basin washwater** from a facility located at **318 Riverview Drive** in **Bluff City, Sullivan County, Tennessee** to receiving waters named **South Fork Holston River at mile 35.6 (Boone Reservoir)** in accordance with effluent limitations, monitoring requirements and other conditions set forth herein. Coverage under this general permit shall become effective on **October 07, 2020** and shall expire on **August 31, 2025**.

<u>External Outfall</u>		<u>001</u>	<u>Effluent Gross</u>			<u>All Year</u>		
<u>Code</u>	<u>Parameter</u>		<u>Qualifier</u>	<u>Value</u>	<u>Unit</u>	<u>Sample Type</u>	<u>Frequency</u>	<u>Statistical Base</u>
00400	pH		<=	9.0	SU	Grab	Weekly	Daily Maximum
00400	pH		>=	6.5	SU	Grab	Weekly	Daily Minimum
00530	Total Suspended Solids (TSS)		<=	40	mg/L	Grab	Weekly	Daily Maximum
00545	Settleable Solids		<=	.5	mL/L	Grab	Weekly	Daily Maximum
01105	Aluminum, total (as Al)		<=	10	mg/L	Grab	Weekly	Daily Maximum
50050	Flow		Report		MGD	Instantaneous	Weekly	Daily Maximum
50060	Chlorine, total residual (TRC)		<=	0.34	mg/L	Grab	Weekly	Daily Maximum