



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
JACKSON ENVIRONMENTAL FIELD OFFICE
1625 HOLLYWOOD DRIVE
JACKSON, TENNESSEE 38305-4316
PHONE (731) 512-1300 STATEWIDE 1-888-891-8332 FAX (731) 661-6283

May 6, 2018

The Honorable Robert T. Kenton III
Mayor, City of Bruceton
209 Cheatham
Bruceton, TN 38317

Cc: Bruceton Wastewater Treatment Facilities Inspection
NPDES NO. TN0062014
Carroll County

Dear Mayor Kenton:

Pursuant to the Tennessee Code Annotated Section, 68-13-103, I conducted an inspection on April 27, 2018 of the wastewater facilities serving the City of Bruceton. The only area to be concerned with is excessive Inflow and/or infiltration which may result in percent removal permit requirements to be difficult to meet. The City must develop a collection system program to locate and eliminate areas of extraneous flows from entering the collection system.

Generally speaking, the wastewater system is well maintained and operated. The City is commended for efforts to protect the waters of the State. I appreciate the courtesy shown to me during my visit. If you have any questions or comments about this correspondence do not hesitate to contact me at 731-512-1313.

Sincerely,

Roger Orgain, Environmental Scientist
Department of Environment and Conservation
Division of Water Resources

Cc: File
NCO