

**Wartburg STP - TN0028622**

	Month	Year	# of TP Samples Taken	Reported TP Monthly Load (lbs.)	TP - Annual Rolling Load (lbs./year)	# of TN Samples Taken	Reported TN Monthly Load (lbs.)	TN - Annual Rolling Load (lbs./year)
Enter the previous year's data in columns E, F, H & I	January	2022	1	0.9		1	7.4	
	February	2022	1	1.5		1	7.1	
	March	2022	1	0.4		1	20.5	
	April	2022	1	0.3		1	4.7	
	May	2022	1	2.1		1	13.8	
	June	2022	1	6.3		1	7.0	
	July	2022	1	6.5		1	8.4	
	August	2022	1	8.0		1	18.9	
	September	2022	1	1.9		1	8.1	
	October	2022	1	4.4		1	5.2	
	November	2022	1	5.2		1	5.5	
	December	2022	1	2.6	1,219.7	1	23.0	3,942.0
This year's data the 12 month running load will calculate automatically	January	2023	1	3.7	1,305.0	1	6.4	3,910.8
	February	2023	1	2.2	1,325.1	1	7.9	3,936.5
	March	2023	1	0.6	1,331.1	1	10.0	3,616.8
	April	2023	1	2.2	1,387.8	1	9.7	3,768.6
	May	2023	1	2.6	1,401.5	1	9.4	3,635.6
	June	2023	1	6.1	1,395.4	1	4.7	3,566.6
	July	2023	1	11.8	1,555.7	1	10.2	3,620.1
	August	2023	1	9.2	1,593.1	1	10.3	3,359.0
	September	2023	1	2.9	1,623.1	1	3.4	3,216.1
	October	2023	1	2.5	1,565.5	1	4.4	3,193.1
	November	2023	1	7.3	1,629.3	1	18.4	3,585.6
	December	2023	1	1.8	1,604.8	1	6.8	3,094.0

**Optimization Target Annual Load**

**Phosphorus, Total (as P):**

6,573.0 lbs./year

**Rolling Annual Load**

NPDES Permit:

**Nitrogen, Total (as N):**

22,110.0 lbs./year

**Rolling Annual Load**

NPDES Permit: