

Wade Murphy

From: Bains, Susanna <Bains.Susanna@epa.gov>
Sent: Thursday, February 29, 2024 10:43 AM
To: Wade Murphy
Cc: Holliman, Daniel; Vojin Janjic
Subject: [EXTERNAL] RE: Revised Final Draft in Consideration of EPA comments on Memphis Regional Megasite WWTP (TN0081906)

***** This is an EXTERNAL email. Please exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email - STS-Security. *****

Hi Wade,

Happy Leap Day! Thank you for sending this over. We have reviewed the revisions and we appreciate the addition of the 90-day deadline for the start-up phase. We approve of this final draft and our review is complete.

Thanks,

Susanna Bains
NPDES Permitting Section
Water Division, EPA Region 4
404-562-9747

From: Wade Murphy <Wade.Murphy@tn.gov>
Sent: Wednesday, February 28, 2024 3:57 PM
To: Bains, Susanna <Bains.Susanna@epa.gov>; Vojin Janjic <Vojin.Janjic@tn.gov>
Cc: Holliman, Daniel <Holliman.Daniel@epa.gov>
Subject: Revised Final Draft in Consideration of EPA comments on Memphis Regional Megasite WWTP (TN0081906)

Caution: This email originated from outside EPA, please exercise additional caution when deciding whether to open attachments or click on provided links.

Good afternoon everyone. This being a leap year, you've got a whole extra day to review this before the end of February!

Susanna, I'm pleased to send this revised final draft permit in consideration of the comments below. The Division will refrain from issuing this permit until we receive the go-ahead from EPA Region IV. The revisions are limited to Pages AM-1 (after Page 49) and Pages 1-3 of the permit.

Kind regards,



Wade D. Murphy | E.I.
Division of Water Resources, Water-Based Systems Unit
William R. Snodgrass TN Tower, 11th Fl

312 Rosa L. Parks Ave 37243
p. 615-532-0666
wade.murphy@tn.gov
tn.gov/environment

We value your feedback! Please complete our [customer satisfaction survey](#).

From: Bains, Susanna <Bains.Susanna@epa.gov>
Sent: Thursday, February 15, 2024 11:13 AM
To: Vojin Janjic <Vojin.Janjic@tn.gov>
Cc: Wade Murphy <Wade.Murphy@tn.gov>; Holliman, Daniel <Holliman.Daniel@epa.gov>
Subject: [EXTERNAL] EPA comments on Memphis Regional Megasite WWTP (TN0081906)

Vojin,

In accordance with the U.S. Environmental Protection Agency/State of Tennessee Memorandum of Agreement (MOA) Section IV, EPA is providing the below comment and recommendation to the above-referenced draft individual National Pollutant Discharge Elimination System (NPDES) Permit and supporting documents received by the EPA on January 23, 2024.

- Federal regulations at 40 CFR § 122.29(d)(4) state that within the shortest feasible amount of time (not to exceed 90 days), the owner or operator of a new source or new discharger shall “start-up” all pollution control equipment required to meet all the conditions of its permit.
- EPA recommends allowing up to 90 days from the initiation of start-up to the completion of start-up and enforceability of all effluent limits.
- Note that secondary treatment effluent limits are not eligible for a longer compliance schedule under 40 CFR § 122.47.

Prior to the issuance of a final permit, TDEC is responsible for compiling all significant comments received during the public comment period and responding to all significant comments in accordance with 40 CFR § 124.17(a). EPA requests to review the proposed final permit prior to issuance.

This concludes our review of the draft permit. If you have any questions about the comment and recommendation, please let me know.

Thanks,

Susanna Bains
NPDES Permitting Section
Water Division, EPA Region 4
404-562-9747