

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
Division of Water Resources
William R. Snodgrass - Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243-1102

MR. DAVID A. SCHMIDT
VICE PRESIDENT
ATC GROUP SERVICES, LLC
3144 STAGE POST DRIVE, SUITE 112
BARTLETT, TN 38133
e-copy: david.schmidt@atcgs.com

**UST Groundwater Remediation NPDES General Permit
Notice of Coverage Fact Sheet**

The Division of Water Resources received from your company a Notice of Intent (NOI) to be covered under the General NPDES Permit for Discharges of Treated Groundwater Associated with Underground Storage Tank Remediation (UST GP). **We have recorded site information and are hereby notifying you that this groundwater remediation site is covered under the UST GP.**

Enclosed with this fact sheet you will find a Notice of Coverage (NOC) with the permit tracking number (TNG830237), facility's name, address and receiving stream information that apply to your facility/site. In order to get a copy of the UST GP requirements we ask you to visit our web site: <https://www.tn.gov/environment/permit-permits/water-permits1/npdes-permits1/underground-storage-tank-remediation-npdes-general-permit.html>

We will provide you with a printed copy of the UST GP only upon your request.

At our web site, you will be able to download permit requirements, as well as permit rationale, Notice of Determination, guidance documents and find links to relevant web sites. If you do not have access to the web, or have other questions, call us at (888) 891-TDEC or contact us by E-mail at David.C.Matthews@tn.gov.


Thank you for your time and assistance.

Sincerely,



Vojin Janjic
Manager, Water-Based Systems

cc: Geina Skinner, Division of Underground Storage Tanks, Nashville, Geina.Skinner@tn.gov
Division of Water Resources - Permit File & Jackson EFO
Erica Fey, Division of Water Resources, Erica.Fey@tn.gov



Tracking No. TNG830237

Notice of Coverage under the
General NPDES Permit for Discharges of Treated Groundwater Associated with
UNDERGROUND STORAGE TANK REMEDIATION

Tennessee Department of Environment and Conservation
Division of Water Resources
William R. Snodgrass - Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243-1102

Under authority of the Tennessee Water Quality Control Act of 1977 (T.C.A. 69-3-101 *et seq.*) and the delegation of authority from the United States Environmental Protection Agency under the Federal Water Pollution Control Act, as amended by the Clean Water Act of 1977 (33 U.S.C. 1251, *et seq.*):

Discharger: **ATC Group Services LLC**

Is authorized to discharge: **Treated groundwater associated with underground storage tank remediation**

From a site located: **at 588 Old Hickory Boulevard Old Hickory Express FKA Old Hickory Citgo in Jackson, Madison County
Latitude: 35.657594, Longitude: -88.849912**

To receiving waters named: **Wet weather conveyance to South Fork Forked Deer River**

In accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

Coverage under this general permit shall become effective on **October 01, 2018**

and shall expire on **September 30, 2023**

Notice of Coverage issued: **September 12, 2018**

UST General Permit is located at <https://www.tn.gov/environment/permit-permits/water-permits1/npdes-permits1/underground-storage-tank-remediation-npdes-general-permit.html>

EFFLUENT LIMITS

Discharges covered by this permit must comply with the following numerical effluent limits:

Description : External Outfall, Number : 001, Monitoring : All Weather, Season : All Year							
Parameter	Qualifier	Value	Unit	Sample Type	Monitoring Frequency	Statistical Base	
pH	<	6.5	SU	Grab	Quarterly	Daily Minimum	
pH	<	9.0	SU	Grab	Quarterly	Daily Maximum	
Total Suspended Solids (TSS)	<=	40	mg/L	Grab	Quarterly	Daily Maximum	
Lead, total recoverable	<=	.45	mg/L	Grab	Quarterly	Daily Maximum	
Toluene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum	
Benzene	<=	.005	mg/L	Grab	Quarterly	Daily Maximum	
Ethylbenzene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum	
Floating solids or visible foam-visual	Report	-	Y=1;N=0	Visual	Quarterly	Daily Maximum	
Flow	Report	-	Mgal/d	Instantaneous	Quarterly	Daily Maximum	
Xylene	<=	.01	mg/L	Grab	Quarterly	Daily Maximum	
IC25 Static Renewal 7 Day Chronic Ceriodaphnia	<	100	% survival	Composite	See Permit	Daily Maximum	
IC25 Static Renewal 7 Day Chronic Pimephales promelas	<	100	% survival	Composite	See Permit	Daily Maximum	

If WET testing did show effluent toxicity during the previous permit cycle, annual testing will be required for the duration of the permit. If applicable, WET testing shall commence within 180 days from the effective date of this permit.

In the event of a test failure, the permittee must schedule a follow-up test within 2 weeks and submit results from a follow-up test within 30 days from obtaining initial WET testing results. The follow-up test must be conducted using the same serial dilutions as presented in the corresponding table above.