

DISTRIBUTION SAMPLE SHEET

City of Clarksville
 Water Treatment Plant
 P.O. Box 387
 Clarksville, TN 37043
 August 2016
 (931) 553-2440
 PWSID - 0000116

	Address	Date	CL2	pH Distribution	Iron	Manganese	Fluoride	Phosphate Entry Point	Phosphate Distribution
1	1515 Vista	8/1/16	2.1	7.5	0.01	0.015	0.49	0.35	0.39
2	1539-B Ashland City Rd	8/2/16	2.2	7.5	0.01	0.031	0.47	0.35	0.36
3	1579 Boxcroft Rd	8/3/16	1.2	7.6	0.01	0.039	0.48	0.30	0.45
4	660 Horace Crow Dr	8/4/16	2.1	7.6	0.03	0.004	0.47	0.39	0.40
5	1295 Paradise Hill Rd	8/5/16	1.7	7.5	0.01	0.007	0.50	0.31	0.27
6	210-A Needmore Rd	8/8/16	1.1	7.7	0.03	0.015	0.47	0.47	0.49
7	1921 Madison St	8/9/16	2.4	7.5	0.01	0.005	0.47	0.43	0.45
8	1844 Memorial Dr	8/10/16	1.0	7.4	0.01	0.009	0.50	0.52	0.49
9	1111 Merchants Blvd	8/11/16	1.8	7.4	0.01	0.013	0.53	0.31	0.42
10	2537 Wilma Rudolph Blvd	8/12/16	2.0	7.4	0.02	0.033	0.32	0.33	0.50
11	730 Economy Dr	8/15/16	1.6	7.7	0.02	0.015	0.54	0.52	0.62
12	308 Old Dunbar Cave Rd	8/16/16	2.5	7.6	0.01	0.015	0.52	0.29	0.50
13	251 Timber Court Dr	8/17/16	2.5	7.6	0.01	0.015	0.53	0.45	0.50
14	957 Commerce St	8/18/16	2.8	7.5	0.01	0.011	0.51	0.47	0.50
15	280 Dunbar Cave Rd	8/19/16	2.7	7.5	0.00	0.016	0.50	0.29	0.57
16	155 Edmondson Ferry Rd	8/22/16	2.1	7.6	0.01	0.012	0.48	0.32	0.44
17	128 Public Square	8/23/16	2.5	7.6	0.03	0.009	0.47	0.53	0.55
18	1029 S. Riverside Dr	8/24/16	1.9	7.5	0.01	0.010	0.46	0.41	0.59
19	580 Fire Station Rd	8/25/16	1.9	7.4	0.02	0.013	0.46	0.40	0.44
20	809 Kraft St	8/26/16	1.9	7.7	0.01	0.013	0.54	0.26	0.56
21	1271 Dudley Rd	8/29/16	1.9	7.4	0.00	0.019	0.54	0.25	0.37
22	1105 Riverwood Pl	8/30/16	2.3	7.4	0.00	0.015	0.52	0.33	0.36
23	421 New Providence Blvd	8/31/16	2.3	7.5	0.01	0.019	0.51	0.34	0.54
24									
25									
		Total	46.5	173.1	0.29	0.353	11.28	8.62	10.76
		Avg	2.0	7.5	0.01	0.015	0.49	0.37	0.47
		Max	2.8	7.7	0.03	0.039	0.54	0.53	0.62
		Min	1.0	7.4	0.00	0.004	0.32	0.25	0.27