

PERMIT NUMBER	PERMIT FEATURE TYPE DESCRIPTION	PERMIT FEATURE ID	YEAR	MONTH	DATE	RAINFALL (0.1 inch)	INFLUENT FLOW (MGD)	EFFLUENT FLOW (MGD)	HOURS BYPASSED	CO ₂ EFFLUENT (mg/L)	CO ₃ EFFLUENT (POUNDS)	Ammonia N EFFLUENT (mg/L)	Ammonia N EFFLUENT (POUNDS)	TSS EFFLUENT (mg/L)	TSS EFFLUENT (POUNDS)	DO EFFLUENT (mg/L)	pH EFFLUENT (S. U.)	Less Than (-) Suspended Solids EFFLUENT (mg/L)	Less Than (-) E. coli	EFFLUENT E.COU	Less Than (-) TRC	EFFLUENT TOTAL CHLORINE RESIDUAL (mg/L)					
TN0057878	External Outfall	001	2024	February	1			0.001								8.3	7.8					0.020					
TN0057878	External Outfall	001	2024	February	2			0.000								7.8	7.4	0.1				0.020					
TN0057878	External Outfall	001	2024	February	3																						
TN0057878	External Outfall	001	2024	February	4																						
TN0057878	External Outfall	001	2024	February	5			0.001								8.6	7.4	0.1		43.7		0.010					
TN0057878	External Outfall	001	2024	February	6			0.001						5.0	0.0	9.0	7.4					0.020					
TN0057878	External Outfall	001	2024	February	7			0.001								8.9	7.2	0.2				0.010					
TN0057878	External Outfall	001	2024	February	8			0.001								9.1	7.4					0.000					
TN0057878	External Outfall	001	2024	February	9			0.002								9.3	7.1					0.000					
TN0057878	External Outfall	001	2024	February	10																						
TN0057878	External Outfall	001	2024	February	11																						
TN0057878	External Outfall	001	2024	February	12			0.002								9.5	6.8					0.010					
TN0057878	External Outfall	001	2024	February	13			0.001								10.2	6.5					0.020					
TN0057878	External Outfall	001	2024	February	14			0.001								8.7	6.5	0.1				0.020					
TN0057878	External Outfall	001	2024	February	15			0.001								9.4	7.7					0.010					
TN0057878	External Outfall	001	2024	February	16			0.001								9.4	7.1	0.1				0.000					
TN0057878	External Outfall	001	2024	February	17																						
TN0057878	External Outfall	001	2024	February	18																						
TN0057878	External Outfall	001	2024	February	19																						
TN0057878	External Outfall	001	2024	February	20			0.001								9.1	7.5	0.2				0.010					
TN0057878	External Outfall	001	2024	February	21			0.001		4.0	0.0	0.271	0.002			8.7	7.3					0.010					
TN0057878	External Outfall	001	2024	February	22			0.001								8.2	7.3	0.1				0.000					
TN0057878	External Outfall	001	2024	February	23			0.001								8.9	7.2					0.010					
TN0057878	External Outfall	001	2024	February	24																						
TN0057878	External Outfall	001	2024	February	25																						
TN0057878	External Outfall	001	2024	February	26			0.001								9.3	6.7	0.1				0.020					
TN0057878	External Outfall	001	2024	February	27			0.001								9.4	7.2					0.020					
TN0057878	External Outfall	001	2024	February	28			0.000								9.1	7.3					0.020					
TN0057878	External Outfall	001	2024	February	29			0.001								9.8	6.8					0.010					
I certify under penalty of law that this document and all attachments were prepared under my direction and supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.						TOTAL	0.00	0.000	0.020	0.0		0.0	0.002		0.0												
						AVERAGE	#DIV/0!	0.001			4.0	0.0	0.271	0.002	5.0	0.0	9.0				0.1		43.7				0.012
						MAXIMUM	0.00	0.000	0.002	0.0	4.0	0.0	0.271	0.002	5.0	0.0	10.2	7.8			0.2		43.7				0.020
						MINIMUM		0.000	0.000		4.0	0.0	0.271	0.002	5.0	0.0	7.8	6.5			0.1		43.7				0.000
PERMIT LIMIT DAILY MAX										20.0	0.0	10.000	0.000	45.0	9999.0		9.0	1.0		941.0		0.020					
PERMIT LIMIT DAILY MIN																3.0	6.0										
PERMIT LIMIT MONTHLY WKLY/AVG										10.0	0.0	5.000	0.000	30.0	0.0	0.0				128.0		0.000					

*E. Coli geomean is shown in the Average row

Michael Leest
Signature

Dutch Valley
Elementary School
Plant

3
Grade

4319
Certification #

Anderson
County

Scanned with CamScanner