

Date	meter	use	# Occupied Sites	use/occ site	# sites	use/site	Notes
1/17/2023	0	0	41	0	63	0	Installed 3pm, 60 gallons to refill
1/18/2023	1850	1850	41	45.12	63	29.37	3 pm reading
1/19/2023	3328	1478	42	35.19	63	23.46	1200 reading
1/20/2023	4918	1590	42	37.86	63	25.24	0855 reading
1/21/2023	7371	2453	44	55.75	63	38.94	
1/22/2023	9591	2220	44	50.45	63	35.24	0915 reading
1/23/2023	11419	1828	40	45.70	63	29.02	0850 reading
1/24/2023	14045	2626	41	64.05	63	41.68	1039 reading
1/25/2023	15821	1776	39	45.54	63	28.19	
1/26/2023	16833	1012	39	25.95	63	16.06	
1/27/2023	19155	2322	38	61.11	63	36.86	
1/28/2023	22152	2997	40	74.93	63	47.57	water leak due to freeze
1/29/2023	25458	3306	41	80.63	63	52.48	water leak due to freeze
1/30/2023	27543	2085	41	50.85	63	33.10	11:45 am reading
1/31/2023	29827	2284	40	57.10	63	36.25	
2/7/2023	50523	20696	286	72.36	441	46.93	water leak at a site
2/14/2023	73123	22600	273	82.78	441	51.25	water leak at a site
2/21/2023	88053	14930	267	55.92	441	33.85	
2/28/2023	97742	9689	268	36.15	441	21.97	
3/7/2023	108062	10320	323	31.95	441	23.40	
3/14/2023	123378	15316	317	48.32	441	34.73	
3/21/2023	138936	15558	326	47.72	441	35.28	
3/28/2023	154636	15700	322	48.76	441	35.60	
4/4/2023	171834	17198	355	48.45	441	39.00	
4/11/2023	185542	13708	333	41.17	441	31.08	
4/18/2023	203598	18056	353	51.15	441	40.94	Leak at site... guest connection
4/25/2023	221294	17696	340	52.05	441	40.13	Park model leak
5/2/2023	239784	18490	323	57.24	441	41.93	Leak fixed in Park Model
5/9/2023	257789	18005	285	63.18	441	40.83	

	use per occupied site		use divided by total sites	
		Days		Days
Average per site per day daily readings	52.16	14	33.82	14
Average per site per day weekly readings	52.66	98	36.18	98
Average Use:	52.59		35.89	