TENNESSEE DEPARTMENT OF PUBLIC HEALTH

DIVISION OF WATER QUALITY

REPORT OF OPERATION OF SEWER TREATMENT PLANT FOR March, 2024 AT AEROJET, JONESBOROUGH, WASHINGTON COUNTY

		INFLUEN	IT		MIXED LIQUOR			EFFLUENT								SLUDGE DISPOSAL		
DATE	TIME	WASTE FLOW	B.O.D.	TSS	рΗ	SETTLE SOLIDS	D.O. AERATION	B.O.D.	TSS	SETTLE	DISSOLV. OXYGEN	RESIDUAL	E-COLI	рH	AMMONIA NITROGEN	CLA. SLUDGE DEPTH	WASTE TO HOLD TANK	HOLD TANK
		GAL/MIN	Mg/L	Mg/L	S.U.	MI/L	Mg/L	Mg/L	Mg/L	MI/L	Mg/L	Mg/L	/100ml	S.U.	Mg/L	FEET	GAL	GAL
											73,53,7						177704	
1																		
2																		
3														_				
4																		
- 5	1630	1.84			6.8	640	4.7			<0.1	5.7	MNR	4.2	6.9				
6										1011	0.1	- Million	714	0.0				
7	1615	2.7	27.5	350	6.6	750	5.1	<5	12	<0.1	6.3	MNR		6.6	<0.100			
8			27.13		- 0,0	100	0.1		- 1.	10.1	0.0	MINIX		0.0	<0.100			
9										_								
10																		
11		-																
12	1630	1.46			6.9	COO				-0.4								
13	1030	1,40			0.9	680	5.5			<0.1	7.3	MNR	138.7	6.9				
14	1630	47	400	250	7.4	400	4.0											
	1630	1.7	189	250	7.1	400	4.6	<5	10	<0.1	6.7	MNR		7.2	<0.100			
15																		
16																		
17																		
18																		
19	1600	0.86			7	850	9			<0.1	8.5	MNR		7.2			_	
20																		
21	1700	1.51			6.8	670	5.9			<0.1	6.3	MNR		6.7				
22																		
23																		
24									ļ <u></u>			1						
25																		
26	1600	0.83			6.8	770	6.2			<0.1	7.5	MNR		6.8				
27																		
28	1730	0.96			7.5	420	6.1			<0.1	8.3	MNR		7.6			1100	1100
29														7,0			1100	1100
30																		
31																		
TOTAL		11.86	216.5	600	55.5	5180	47.1	<5	22	0.92	56.6	MNR	142.9	55.9	< .2	0		
AVG.		1.4825	108.25	300	6.9375	5180	5.8875	<5	11	0.3	7.08	MNR	71.45	6.9875	< .1	#DIV/0!	0	(
MAX.		2.7	189	350	7.5	850	9	<5	12	<0.1	8.50	MNR	138.7	7.6	< .1	0	0	
MIN.		0.83	27.5	250	6.6	400	4.6	< 5.0	10	< 0.1	5.7	MNR	4.2	6.6	<.1	0	0	(
												GEO. MEAN	24.135865	0.0	7.1		- 0	

ANALYSES PERFORMED BY OUTSIDE LABORATORY YES LABORATORY USED Waypoint Analytical

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER Aun DATE 4/3/2024

RECEIVED

DATE 4/3/2024

RECEIVED

DATE 4/3/2024

RECEIVED

DATE 4/3/2024

JOHNSON CITY ENV. FIELD OFFICER

I certify that the submitted information is accurate and complete. I further certify that all sampling was performed in accordance with approved procedures and all analyses were performed in accordance with