



Jackson Energy Authority

June 21, 2023

Tennessee Department of Environment and Conservation
TDEC Division of Water Resources
William R. Snodgrass TN Tower
312 Rosa L. Parks Avenue – Eleventh Floor
Nashville, Tennessee 37243

RE: Hicksville SA WW Rehab P1

To Whom it May Concern:

Please find enclosed for your approval (1) set of plans for a project that is to be completed for Jackson Energy Authority's wastewater system. This project is located in Jackson, Madison County. It consists of installing approximately 285 LF of 15" SDR-26 PVC main and 545 LF of 12" SDR-26 PVC main and the abandonment of approximately 1,146 LF of 10", 12", and 15" concrete wastewater piping. We have conducted an analysis and confirmed by computer modeling that the system has adequate capacity and that the project will not create or exacerbate any overflow problems. Sanitary flows associated with this project are received by the Miller WWTP (State Permit # TN0024813).

A payment was made by credit card via TDEC's online submittal portal.

If we may be of further assistance during your review/approval process, please contact me at (731) 422-7580.

Sincerely,

JACKSON ENERGY AUTHORITY

Jeremy D. Harwell, P.E.
Water/Wastewater System Engineer

