



# DIVISION OF LABORATORY SERVICES

Kara Levinson, PhD., MPH, D(ABMM), Director  
 Nashville Central Laboratory  
 Nashville, TN 37216  
 615-262-6300

George J Dizikes, PhD., HCLD/CC(ABB), Director  
 Knoxville Regional Laboratory  
 Knoxville, TN 37920  
 865-549-5201

Print Date: 5/4/2023

## Final Report

Accession #: K2305031

**Accession Number:** K2305031-01

**Location Code:**

**Sample Location:** 469 Roses Creek

**Water System:** Clearfork Utlity District

**Address:** 5667 Hwy 90  
 Clairfield, TN 37715

**PWSID Number:** 826

**Sample Source:** Drinking Water

**Sample Type:** (D) Distribution

**Sample Collector:** Josh Taylor

**Phone:**

**Repeat Sample Location:**

**Reason for retest:**

**County:** Campbell - 07

**Sampling Agency:** Knoxville EFO

**Chlorine Residual:** 1.6

**Date/Time Collected:** 05/02/2023 11:45

**Date Received:** 05/03/2023

**TEST:** Coliforms P-A

**PERFORMING LAB:** Knoxville Regional Laboratory

**METHOD:** 9223-B

ANALYTE	RESULT	UNITS	Qual	DATE
Total Coliform	Absent			5/4/2023
Escherichia coli	Absent			5/4/2023

System Administrator  
 Clearfork Utlity District  
 P.O. Box 63  
 Clairfield, TN 37715

Accession Number: K2305031-02  
Location Code:  
Sample Location: 4244 Hwy 90  
Water System: Clearfork Utility District  
Address: 5667 Hwy 90  
Clairfield, TN 37715

PWSID Number: 826  
Sample Source: Drinking Water  
Sample Type: (D) Distribution

Sample Collector: Josh Taylor  
Phone:  
Repeat Sample Location:  
Reason for retest:  
County: Campbell - 07  
Sampling Agency: Knoxville EFO  
Chlorine Residual: 2.0  
Date/Time Collected: 05/02/2023 12:05  
Date Received: 05/03/2023

TEST: Coliforms P-A  
PERFORMING LAB: Knoxville Regional Laboratory  
METHOD: 9223-B

ANALYTE	RESULT	UNITS	Qual	DATE
Total Coliform	Absent			
Escherichia coli	Absent			5/4/2023
				5/4/2023