

PERMIT NUMBER	PERMIT FEATURE TYPE DESCRIPTION	PERMIT FEATURE ID	YEAR	MONTH	DATE	RAINFALL (0.1 inch)	INFLUENT FLOW (MGD)	EFFLUENT FLOW (MGD)	HOURS BYPASSED	CBOD <sub>5</sub> EFFLUENT (mg/L)	CBOD <sub>5</sub> EFFLUENT (POUNDS)	Ammonia N EFFLUENT (mg/L)	Ammonia N EFFLUENT (POUNDS)	TSS EFFLUENT (mg/L)	TSS EFFLUENT (POUNDS)	DO EFFLUENT (mg/L)	pH EFFLUENT (S. U.)	Less Than (<) Settleable Solids Effluent (mL)	Less Than (<) E.coli	EFFLUENT E.COLI	Less Than (<) TRC	EFFLUENT TOTAL CHLORINE RESIDUAL (mg/L)	
																							TOTAL
TN0057878	External Outfall	001	2023	June	1			0.000				1.850	0.000	3.0	0.0	8.0	7.8					43.7	0.01
TN0057878	External Outfall	001	2023	June	2			0.000								7.7	7.8						0.01
TN0057878	External Outfall	001	2023	June	3																		
TN0057878	External Outfall	001	2023	June	4											8.9	7.4						
TN0057878	External Outfall	001	2023	June	5			0.000								7.7	7.8	0.1					0.01
TN0057878	External Outfall	001	2023	June	6			0.000								8.0	7.0	0.1					0.02
TN0057878	External Outfall	001	2023	June	7			0.000		2.0	0.0					8.8	7.0	0.1					0.01
TN0057878	External Outfall	001	2023	June	8			0.000								8.6	7.8						0.02
TN0057878	External Outfall	001	2023	June	9																		
TN0057878	External Outfall	001	2023	June	10																		
TN0057878	External Outfall	001	2023	June	11																		
TN0057878	External Outfall	001	2023	June	12			0.000								7.9	7.7						0.01
TN0057878	External Outfall	001	2023	June	13			0.000								7.5	7.7						0.01
TN0057878	External Outfall	001	2023	June	14			0.000								7.6	7.7	0.1					0.01
TN0057878	External Outfall	001	2023	June	15			0.000								7.3	7.7						0.01
TN0057878	External Outfall	001	2023	June	16			0.000								7.4	7.7						0.01
TN0057878	External Outfall	001	2023	June	17																		
TN0057878	External Outfall	001	2023	June	18											8.1	7.9	0.1					0.01
TN0057878	External Outfall	001	2023	June	19			0.003								8.6	7.4						0.02
TN0057878	External Outfall	001	2023	June	20			0.002								8.5	7.4	0.1					0.02
TN0057878	External Outfall	001	2023	June	21			0.001								8.6	7.6						0.01
TN0057878	External Outfall	001	2023	June	22			0.000								9.2	7.5						0.01
TN0057878	External Outfall	001	2023	June	23																		
TN0057878	External Outfall	001	2023	June	24																		
TN0057878	External Outfall	001	2023	June	25			0.001								7.8	7.5						0.01
TN0057878	External Outfall	001	2023	June	26			0.000								7.5	7.4	0.1					0.01
TN0057878	External Outfall	001	2023	June	27			0.000								7.3	7.4						0.00
TN0057878	External Outfall	001	2023	June	28			0.000								7.5	7.4	0.1					0.01
TN0057878	External Outfall	001	2023	June	29			0.001								8.2	7.4						0.01
TN0057878	External Outfall	001	2023	June	30			0.000															0.01
Certify under penalty of law that this document and all information provided hereunder is true and correct to the best of my knowledge and belief, true, accurate, and complete. I am the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware of the consequences of providing false or misleading information, including the possibility of fine and imprisonment for knowing violations.																							
I certify under penalty of law that this document and all information provided hereunder is true and correct to the best of my knowledge and belief, true, accurate, and complete. I am the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware of the consequences of providing false or misleading information, including the possibility of fine and imprisonment for knowing violations.																							
*E. Coli geometric mean is shown in the Average row.																							
PERMIT LIMIT DAILY MAX PERMIT LIMIT MONTHLY WQV/AVG																							

*Michael Faust*  
Signature

Dutch Valley  
Elementary School  
Plant

3  
Grade

4319  
Certification #

Anderson  
County