



October 29, 2009

Certified Mail 7007 0710 0003 2990 0687
Return Receipt Requested

Mr. Jeff Prine
Skyridge Medical Center
2305 Chambliss Avenue, NW
Cleveland, TN 37311

Re.: Request for Permit Application Submittal

Dear Mr. Prine:

As required by State of Tennessee Rules 1200-3-9-.01(1) (a) and 1200-3-9-.02(2), any and all air contaminant source(s) having been, or to be, constructed or operated at your facility must be permitted by this Division **unless specifically exempted in Rule 1200-3-9-.04.**

During an investigation of your facility on October 28, 2009, you were found to be operating three new natural gas-fired boilers without a permit issued by this agency. Applications for this operation must be submitted **within thirty (30) days of receipt of this letter** on the enclosed forms. Original application forms must be submitted to the Division of Air Pollution Control Nashville Central Office at the address listed on the forms. A copy of the applications must be submitted to the Chattanooga Environmental Field Office at the above address. This information is requested under the authority granted by T.C.A. 68-201-105(b) (2). Please be advised that compliance with all applicable requirements is the responsibility of the source owner/operator.

If further clarification is needed, please call me at 423-634-7127.

Sincerely,

Stephanie Dyer
Environmental Specialist
Division of Air Pollution Control
Chattanooga Environmental Field Office