

From: [Julie Verissimo](#)
To: [APC Permitting](#)
Cc: [Michael Vergamini](#); [John Fuss](#)
Subject: Cleveland Hospital Company, LLC (06-0056)
Date: Tuesday, September 27, 2022 9:21:12 AM
Attachments: [image001.png](#)
[Source 04 - 800 kW Generator - Insignificant Request.pdf](#)

Good morning,

When possible, please create a new Insig Activity/Exemption log for Facility ID 06-0056. Please add Point #04 to this log. The attached document can be uploaded as the request for this designation.

If you have any questions or need additional information, please let me know.

Thank you!

Julie



Julie Verissimo | Environmental Consultant 3
Division of Air Pollution Control
Tennessee Tower, 15th Floor
312 Rosa L Parks Ave., Nashville, TN 37243
p. 615-532-0582
julie.verissimo@tn.gov



2305 Chambliss Avenue NW
Cleveland, TN 37311
Ph: 423.559.6000

(Westside campus)
2800 Westside Drive NW
Cleveland, TN 37312
Ph: 423.339.4100

August 18, 2022

To Whom It May Concern:

Cleveland Hospital Company LLC dba Tennova Healthcare – Cleveland is requesting lower emission limits for the following sources:

- The boilers (06-0056-01) we request a PM limit of 0.58 pounds of PM per hour
- The boilers (06-0056-01) we request a SO₂ limit of 0.05 pound of SO_x per hour
- The 1,500 kW generator (06-0056-03) we request a PM limit of 4.0 pounds of PM per hour
- The 1,500 kW generator (06-0056-03) we request a SO₂ limit of 5.0 pounds of SO₂ per hour

We also request that our 800 kW generator be considered an insignificant source. Our boilers are operated as gas-fired boilers and only use No. 2 fuel oil as a backup fuel in a limited manner, with no more than 48 hours per year of non-emergency use for periodic testing, maintenance, or operator testing.

A handwritten signature in black ink that reads "Stacey Bostick". The signature is written in a cursive style and is positioned above a horizontal line.

Stacey Bostick
Facilities Manger
Tennova Healthcare - Cleveland