

**Tennova Cleveland Hospital Company, LLC dba Tennova Healthcare – Cleveland
06-0056**

Source 04: 800kW diesel-fired emergency generator

energy rating 800 kw 11073 hp

sulfur content 0.0015 % (15 ppm)

		PM	SO ₂	NMHC + NO _x	CO	VOC
AP-42 Factors	lbs/hp-hr	1.21E-05				
Applicable Standard	g/kW-hr	0.2		6.4	3.5	
Emissions	lbs/hr	0.35	0.13	11.29	6.17	
8760 work-hours	tpy	1.54	0.59	49.44	27.04	
500 work-hours	tpy	0.09	0.034	2.82	1.54	
Permit Limits	lbs/hr	0.35	4.34	11.29	6.17	0.76
	tpy	0.09	1.09	2.82	1.54	0.19

This source shall be considered an insignificant source.

It will continue to comply with the maintenance and recordkeeping requirements of 40 CFR 60, NSPS Subpa

art III.