

From: [Air.Pollution Control](#)
To: [APC Permitting](#)
Subject: FW: CMOP 472842 - US Nitrogen Notification of Temporary Boiler Use - Insignificant Emissions
Date: Monday, April 15, 2024 1:22:08 PM
Attachments: [image001.png](#)
[4.15.24 Notification of Temporary Boiler Use.pdf](#)

From: Gayle Winzenried <Gayle.Winzenried@austinpowder.com>
Sent: Monday, April 15, 2024 12:23 PM
To: Air.Pollution Control <Air.Pollution.Control@tn.gov>
Cc: Kim Ryans <Kim.Ryans@austinpowder.com>; Dylan Charles <Dylan.Charles@austinpowder.com>; Jordan Cheek <Jordan.Cheek@austinpowder.com>; James Johnston <James.Johnston@tn.gov>; Doug S. Wright <Doug.S.Wright@tn.gov>
Subject: [EXTERNAL] CMOP 472842 - US Nitrogen Notification of Temporary Boiler Use - Insignificant Emissions

***** This is an EXTERNAL email. Please exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email - STS-Security. *****

Good day,

On behalf of US Nitrogen, I am submitting a notification of the emergency use of a temporary boiler which qualify as insignificant emission units. If you have further questions, please contact Kim Ryans.

Sincerely,



AUSTIN POWDER

Gayle Winzenried | Environmental, Health & Safety Administrative Coordinator

US Nitrogen, LLC | 471 Pottertown Road, Midway, TN 37809

Office: 423.422.3080 | Fax: 423.422.2050 | Email: Gayle.Winzenried@austinpowder.com



AUSTIN POWDER

April 15, 2024

Submitted Electronically to Air.Pollution.Control@tn.gov

Michelle W. Owenby, Director,
Division of Air Pollution Control
Tennessee Department of Environment and Conservation
William R. Snodgrass Tennessee Tower, 15th Floor
312 Rosa L. Parks Avenue
Nashville, Tennessee 37243

Re: Notification of the Use of Temporary Boilers Which Qualify as an Insignificant Emissions Unit

Dear Ms. Owenby,

On February 23, 2024, US Nitrogen LLC (US Nitrogen), Emission Source Number 30-0248, made notification of the anticipated use of a temporary boiler(s) while the existing permitted auxiliary boiler undergoes annual inspection. At the time of that notification, the specifications for the temporary boiler(s) were not known. The specifications are now known.

The permitted auxiliary boiler is a 113 MMBtu/hr boiler with low-NO_x burners. The permit limits for the currently permitted boiler are as follows:

Pollutant	Permit Limits		Permit Condition
PM	1.00 lb/hr	3.76 tons per 12 consecutive months	S2-4
SO ₂	0.1 lb/hr	0.3 tons per 12 consecutive months	S2-5
NO _x	3.96 lb/hr	17.32 tons per 12 consecutive months	S2-6
CO	4.52 lb/hr	19.80 tons per 12 consecutive months	S2-7
VOC	0.61 lb/hr	2.72 tons per 12 consecutive months	S2-8

There will be two temporary boilers and it is anticipated they will be used for 60 days or less. For the purposes of calculating the emissions from the temporary boilers, we have conservatively assumed they will be used for 60 days. The temporary boilers will have maximum heat input capacities of 12.6 MMBtu/hr (300 hp output) and 10.5 MMBtu/hr (250 hp). Please see the attached specifications.



AUSTIN POWDER

The temporary boilers meet the definition of "temporary boilers" in 40 CFR Subpart Dc due to being:

- Portable (i.e. they can be moved from one location to another by means of, for example, wheels, skids, carrying handles, dollies, trailers, or platforms);
- They will not be attached to a foundation;
- They will be used less than 180 days; and
- They are being used on a temporary basis until the permanent boiler can be inspected.

US Nitrogen believes the temporary boilers each, and in combination, constitute an *insignificant emissions unit* as defined in Tennessee Air Pollution Control Regulations 1200-03-09-.04(2)(a)3 since their use will result in potential emissions of less than five tons per year of each air contaminant and each regulated air pollutant that is not a hazardous air pollutant, and less than 1,000 pounds per year of each hazardous air pollutant. The calculated total emissions for the time the temporary boilers will be used are as follows:

Pollutant	Emissions from Temporary Boilers During Period of Usage (TPY)		
	Temporary Boiler #1	Temporary Boiler #2	Both Boilers
PM	0.07	0.07	0.13
SO ₂	0.01	0.01	0.01
NOx	0.89	0.74	1.62
CO	0.74	0.62	1.36
VOC	0.05	0.04	0.09
Total HAP	0.02	0.01	0.03

The supporting emissions calculations for the temporary boilers are enclosed.

US Nitrogen expects to have the temporary boilers in operation by April 22, 2024.

If you have any questions regarding this request, please contact Kim Ryans at 423-422-2052 or Kim.Ryans@austinpowder.com

Dylan Charles
Plant Manager

Enclosures

300 HP TEMPORARY BOILER SPECIFICATIONS

30 day rental for \$18,000. ~10,000 lbs/hr steam
Justin Steigerwald 513-254-1320
Smith-Hughes Company, Cincinnati, OH

3753 ROUND BOTTOM RD. CINCINNATI, OH 45244

PH 513 271-2226 FAX 513 271-2310 www.smithhughes.com info@smithhughes.com

RB-300A&B (2 Units Available)

**300HP, 900 PSIG Vapor Steam Generators
10,350PPH From and at 212 Deg. F
Natural Gas/Propane-Fired**

**Compatible with Feedwater System
RFWS-300AB**

**Skid-mounted Steam Generator capable of full
output and pressure within 5 minutes.**

Design Details:

- 300HP (2,943 KW)
- 10,350PPH from and at 212 deg F
- Thermal Output: 10,042,500 BTU/Hr
- Construction Codes: ASME, Hartford, Nat. Board
- Fast Start-up
- Compact Size and Low Weight
- Modulating Output
- High Pressure
- Safe Operation

Controls:

- Steam pressure
- Low water cutoff
- Flame failure protection
- Coil temperature limit
- Exhaust stack temperature limit

Burner Requirements:

- 1 psig

Power Requirements:

- 230 or 460 VAC, 3 Ph, 60 Hz

Customer Connections:

- Stack Outlet: 24" OD
- Steam Outlet: 3" x 600# Flanged
- Main Gas Supply: 3" NPT
- Feedwater Inlet: 2-1/2" NPT
- Blowdown Outlet (2): 1" NPT
- Fill Test Valve: 1/2" NPT
- Water Pump Relief Valve: 1/2" NPT
- Trap Return: 1-1/2" NPT
- Safety Valve Outlet (2): 1-1/4" NPT

Dimensions:

- 120" L x 84" W x 131" H
- Approx. Floor Loading: 250#/sq ft




Shipping Weight:

- 17,500 lbs

250 HP TEMPORARY BOILER SPECIFICATIONS

INDUSTRIAL BOILER & MECHANICAL CO
3325 N HAWTHORNE ST
CHATTANOOGA TN 37406
423-629-1117


Low Pressure Steam Rental
Boiler
9/12/2022



BOILER CONNECTIONS		RATINGS & CAPACITIES		LTR	DATE	REVISION	BY	REPRESENTATIVE:
A.(1) STEAM OUTLET	4" 300# FLANGE	HORSEPOWER	250*					
B.(4) LWCO	1" NPT	DESIGN PRESSURE	150 PSIG STEAM					
C.(2) SAFETY VALVE	2" NPT	GROSS OUTPUT	8369 MBH*					
D.() SAFETY VALVE		STEAM (FROM & AT 212°F)	8625 Lbs/HR*					
E.(2) BOILER BLOWDOWN	1 1/4" NPT	HEAT RELEASE: (FURNACE ONLY)	134235 BTU/CuFt*					PROJECT:
F.(2) SURFACE BLOWDOWN	1" NPT	RATED INPUT	10461 MBH*					
G.(1) MANWAY	12" x 16"	HEATING SURFACE (ASME)	1269 SqFt					
H.(5) HANDHOLE	3" x 4"	FURNACE HEATING SURFACE	118.97 SqFt					
J.(1) CLEANOUT PORT	17" ID	FURNACE VOLUME	77.93 CuFt					
K.(2) FEEDWATER	1" NPT	TURNAROUND VOLUME	42.09 CuFt					
L.(1) AUXILIARY/VENT	2" NPT	STEAMING VOLUME	37.70 CuFt					
M.(2) LOW FIRE HOLD	1/2" NPT	STEAM RELEASE AREA	64.68 SqFt					
N.(1) STACK TEMP	1/2" NPT	WATER CAPACITY:						
P.(1) SIGHT PORT	1" NPT	(FULL)	2,200 Gal @ 18,300 Lbs					
Q.(1) NAT GAS	3" NPT 5-10 PSI	(NWL)	1,918 Gal @ 15,954 Lbs					
R.(1) ELECTRICAL	460V 3-PH 20A	SHIPPING WEIGHT:	23,200 Lbs					
S.()								

NOTES

- ALL CONTROLS MOUNTED AS PER SPECIFICATION SHEET.
- SPECIFICATION SHEET TAKES PRIORITY OVER R & D SHEET.
- BOILER DESIGN CODE ASME SECTION I.
- BOILER INSULATED WITH 2" - 8# DENSITY MINERAL FIBER INSULATION WITH 22 GAUGE STEEL JACKET.
- ALL DIMENSIONS ARE $\pm 1/2"$ UNLESS OTHERWISE NOTED.
- HORSEPOWER & RELATED INFO BASED ON 5 SqFt FIRING.



MOHICAN BOILER MODEL
7-5-1250-S150

SCALE

1/54

CHECKED BY

DRAWN BY

?

DATE

DATE

?

THIS DRAWING IS THE PROPERTY OF SUPERIOR BOILER WORKS & SHALL NOT BE REPRODUCED IN PART OR IN WHOLE, & NONE OF ITS INFORMATION SHALL BE REVEALED WITHOUT PERMISSION OR TO THE DETRIMENT OF THE OWNER. IT MUST BE RETURNED UPON REQUEST.

TEMPORARY BOILERS EMISSIONS CALCULATIONS

Process Name - US Nitrogen Temporary Boilers

Maximum Days of Operation	60 days
Maximum Hours of Operation	1440 hr
High Heat Value of Natural Gas	1020 BTU/scf
Rental Boiler #1, Maximum Heat Input	12.6 MMBtu/hr ¹
Rental Boiler #2, Maximum Heat Input	10.5 MMBtu/hr ²

Potential to Emit for Rental Boiler #1 (300 hp)

Pollutant	PM	SO ₂	NO _x	CO	VOC	CO ₂ e	HAP
Emission Factor (lb/MMScf) ³	7.6	0.6	100	84	5.5	120000	1.89
Emissions (lb/hr)	0.09	7.38E-03	1.23	1.03	0.07	1477	0.02
Emissions (TPY)	0.07	0.01	0.89	0.74	0.05	1063	0.02

Potential to Emit for Rental Boiler #2 (250 hp)

Pollutant	PM	SO ₂	NO _x	CO	VOC	CO ₂ e	HAP
Emission Factor (lb/MMScf) ³	7.6	0.6	100	84	5.5	120000	1.89
Emissions (lb/hr)	0.09	6.2E-03	1.03	0.86	0.06	1231	0.02
Emissions (TPY)	0.07	4.4E-03	0.74	0.62	0.04	886	0.01

Potential to Emit for Both Boilers Combined

Pollutant	PM	SO ₂	NO _x	CO	VOC	CO ₂ e	HAP
Emissions (lb/hr)	0.19	0.01	2.26	1.90	0.12	2708	0.04
Emissions (TPY)	0.13	0.01	1.62	1.36	0.09	1949	0.03

1. Based on a thermal output of 10,042,500 BTU/hr (see attached specification sheet) and an 80% efficiency.
2. From boiler drawing (attached) of boiler.
3. From AP-42, Chapter 1.4 Natural Gas Combustion