



**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES**

William R. Snodgrass - Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243-1102

Tracking No. TNG830266

**Notice of Coverage (NOC) under the General NPDES Permit for
UNDERGROUND STORAGE TANK (UST) REMEDIATION**

Under authority of the Tennessee Water Quality Control Act of 1977 (T.C.A. 69-3-101 et seq.) and the delegation of authority from the United States Environmental Protection Agency under the Federal Water Pollution Control Act, as amended by the Clean Water Act of 1977 (33 U.S.C. 1251, et seq.) the following operator is authorized to discharge in accordance with effluent limitations, monitoring requirements and other conditions set forth in the UST general permit.

Permittee Name:	ATC Group Services, LLC - Exit 47 Truck Stop
is authorized to discharge:	treated groundwater associated with UST remediation
from the facility located at:	815 Dancyville Road, Stanton, TN, Haywood County
Latitude and longitude:	35.435556, -89.335833
to waters of the state:	Muddy Creek via Outfall 001
Issuance date:	12/08/2023
Effective date:	12/08/2023
Expiration date:	09/30/2028

General UST permit information and overview can be found [here](#).

CN-0759

RDA 2366

Print

Effluent Limits for Outfall 001

Discharges covered by this permit must comply with the following numerical effluent limits:

Outfall 001							
Code	Parameter	Qualifier	Value	Unit	Sample Type	Monitoring Frequency	Statistical Base
00400	pH	>=	6.5	SU	Grab	Quarterly	Daily Minimum
00400	pH	<=	9	SU	Grab	Quarterly	Daily Maximum
00530	Total Suspended Solids (TSS)	<=	40	mg/L	Grab	Quarterly	Daily Maximum
01051	Lead, total (as Pb)	<=	0.45	mg/L	Grab	Quarterly	Daily Maximum
34010	Toluene	<=	0.01	mg/L	Grab	Quarterly	Daily Maximum
34030	Benzene	<=	0.005	mg/L	Grab	Quarterly	Daily Maximum
34371	Ethylbenzene	<=	0.01	mg/L	Grab	Quarterly	Daily Maximum
45613	Floating solids or visible foam-visual	Report	-	Y=1;N=0	Visual	Quarterly	Value
50050	Flow	Report	-	MGD	Instantaneous	Quarterly	Daily Maximum
81551	Xylene	<=	0.01	mg/L	Grab	Quarterly	Daily Maximum
T7P3B	IC25 Sub-Lethal Static Renewal 7 Day Chronic Ceriodaphnia dubia	>=	100	%	Grab	See Permit *	Daily Minimum
T7P6C	IC25 Sub-Lethal Static Renewal 7 Day Chronic Pimephales promelas	>=	100	%	Grab	See Permit *	Daily Minimum

* WET testing will be required if the permittee is not in compliance with any of the numerical effluent limits for Benzene, Ethylbenzene, Toluene, Xylene, or Lead during the first year from the effective date of this coverage. If an exceedance of any effluent limitation is reported, WET testing shall commence within 180 days from the date an exceedance is reported. WET tests shall be performed for three (3) consecutive months using two appropriate species. If toxicity is determined in any of these tests, annual testing will be required for the duration of the permit. If toxicity is not demonstrated, annual testing will not be required.