

MAR 01 2010



STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION

Division of Air Pollution Control
9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531

FEB 22 2010

Ms. Victoria L. Wagner
East Tennessee Natural Gas, LLC
P.O. Box 1642
Houston, TX 77251-1642

Re: 05-0132-03 30-0183-02 62-0094-03 65-0028-02 78-0086-03
 63375 63376 63378 63383 63380

Dear Ms. Wagner:

This correspondence is in response to your letters dated January 29, 2010. The information that you provided has undergone a preliminary review by the Division.

The Tennessee Air Pollution Control Board has adopted regulations which exempt certain types of operations from permit requirements. Internal combustion driven electric generator sets, when used exclusively for emergency replacement or standby service, and meet the requirements of Rule 1200-3-9-.04(5)(f) 37. do not require a permit.

All applicable air pollution regulations must still be met by your facility

If you have any questions concerning this correspondence, please contact Olga Jacobsen at (615) 532-0581.

Sincerely,

A handwritten signature in cursive script that reads "John A. Trimmer".

John A. Trimmer
Chief, East Tennessee Permit Program

JAT/ODJ

cc: Knoxville Environmental Field Office
 Johnson City Environmental Field Office
 ODJ
 05-0132-03-S2 65-0028-02-S2
 30-0183-02-S2 78-0086-03-S2
 62-0094-03-S2