

JUL 03 2013

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF AIR POLLUTION CONTROL



9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone: (615) 532-0554
FAX: (615) 532-0614

NOT TO BE USED FOR TITLE V APPLICATIONS

PERMIT APPLICATION

Operating Permit
Application & Startup

APC 20

PLEASE TYPE OR PRINT AND SUBMIT IN DUPLICATE FOR EACH EMISSION SOURCE. ATTACH APPROPRIATE SOURCE DESCRIPTION FORMS.

1. ORGANIZATION'S LEGAL NAME <i>American Towers - Providence, TN2 # 308975</i>			/// FOR	APC COMPANY--POINT NO.
2. MAILING ADDRESS (ST/RD/P.O. BOX) <i>P.O. Box 63604</i>			/// APC	APC LOG/PERMIT NO.
CITY <i>Phoenix</i>	STATE <i>AZ</i>	ZIP CODE <i>85082</i>	PHONE WITH AREA CODE <i>602-284-0280</i>	
3. PRINCIPAL TECHNICAL CONTACT <i>Scot Sandefur</i>			PHONE WITH AREA CODE <i>602-284-0280</i>	
4. SITE ADDRESS (ST/RD/HWY) <i>5765 Sevierville Rd</i>			COUNTY NAME <i>Blount</i>	
CITY OR DISTANCE TO NEAREST TOWN <i>Seymour</i>		ZIP CODE <i>37865</i>	PHONE WITH AREA CODE <i>602-284-0280</i>	
5. EMISSION SOURCE NO. (NUMBER WHICH UNIQUELY IDENTIFIES THIS SOURCE) <i>E1</i>		PERMIT RENEWAL YES () NO (<input checked="" type="checkbox"/>)		
6. BRIEF DESCRIPTION OF EMISSION SOURCE				

*Emergency Backup Generator Power- Industrial Generator set: 131 hp / 80kw
with 300 gallon diesel fuel belly tank*

7. TYPE OF PERMIT REQUESTED				
CONSTRUCTION ()	STARTING DATE	COMPLETION DATE	LAST PERMIT NUMBER	EMISSION SOURCE REFERENCE NUMBER
OPERATING (<input checked="" type="checkbox"/>)	DATE CONSTRUCTION STARTED <i>1/14/13</i>	DATE COMPLETED <i>1/31/13</i>	LAST PERMIT NUMBER <i>967065P</i>	EMISSION SOURCE REFERENCE NUMBER <i>OS-0328-01</i>
LOCATION TRANSFER ()	TRANSFER DATE		LAST PERMIT NUMBER	EMISSION SOURCE REFERENCE NUMBER
ADDRESS OF LAST LOCATION				

8. DESCRIBE CHANGES THAT HAVE BEEN MADE TO THIS EQUIPMENT OR OPERATION SINCE THE LAST CONSTRUCTION OR OPERATING PERMIT APPLICATION.

9. SIGNATURE (APPLICATION MUST BE SIGNED BEFORE IT WILL BE PROCESSED) <i>[Signature]</i>		DATE <i>6/28/2013</i>
10. SIGNER'S NAME (TYPE OR PRINT) <i>Scot Sandefur</i>	TITLE <i>Director EHS</i>	PHONE WITH AREA CODE <i>602-284-0280</i>



Permit to Construct or Modify an Air Contaminant Source Issued Pursuant to Tennessee Air Quality Act

Date Issued: May 23, 2013

Permit Number:

967065P

Date Expires: May 22, 2014

Issued To: American Tower Corporation – Providence TN2 #308975

Installation Address:

5765 Sevierville Road
Seymour

Installation Description: Emergency Diesel Fired Generator, 131 HP, 80
KW

Emission Source Reference No.

05-0328-01

NSPS/NESHAP

The holder of this permit shall comply with the conditions contained in this permit as well as all applicable provisions of the Tennessee Air Pollution Control Regulations.

CONDITIONS:

1. The application that was utilized in the preparation of this permit is dated March 20, 2013, and is signed by Scot Sandefur, Director EH&S for the permitted facility. If this person terminates employment or is reassigned different duties and is no longer the responsible person to represent and bind the facility in environmental permitting affairs, the owner or operator of this air contaminant source shall notify the Technical Secretary of the change. Said notification shall be in writing and submitted within thirty (30) days of the change. The notification shall include the name and title of the new person assigned by the source owner or operator to represent and bind the facility in environmental permitting affairs. All representations, agreement to terms and conditions and covenants made by the former responsible person that were used in the establishment of limiting permit conditions on this permit will continue to be binding on the facility until such time that a revision to this permit is obtained that would change said representations, agreements and covenants.

(conditions continued on next page)

TECHNICAL SECRETARY

No Authority is Granted by this Permit to Operate, Construct, or Maintain any Installation in Violation of any Law, Statute, Code, Ordinance, Rule, or Regulation of the State of Tennessee or any of its Political Subdivisions.

NON-TRANSFERABLE

POST AT INSTALLATION ADDRESS

State Requirements

2. The horsepower rating for this source is 131 brake horsepower.

TAPCR 1200-03-09-.01(1)(d) and the application dated March 20, 2013

The Technical Secretary may require the permittee to prove compliance with this horsepower rating.

3. Only diesel fuel that meets the requirements in condition 15 shall be used as fuel for this source.

TAPCR 1200-03-09-.01(1)(d) and the application dated March 20, 2013

Compliance with this requirement shall be assured by maintaining records of fuel usage.

4. Particulate Matter (TSP) emitted from this source shall not exceed 0.6 pounds (lb) per million Btus (MM Btu)(0.55 pounds per hour).

TAPCR 1200-03-06-.02(2)

Compliance with this requirement shall be assured by operating the diesel generator as designed and complying with condition 3.

5. Sulfur dioxide (SO₂) emitted from this source shall not exceed 0.27 pounds per hour based on a daily average.

TAPCR 1200-03-14-.01(3)

Compliance with this requirement shall be assured by operating the diesel generator as designed and complying with condition 3.

6. Volatile organic compounds (VOC) emitted from this source shall not exceed 0.33 pounds per hour based on a daily average.

TAPCR 1200-03-07-.07(2)

Compliance with this requirement shall be assured by operating the diesel generator as designed and complying with condition 3.

7. Nitrogen oxides (NO_x) emitted from this source shall not exceed 4.06 pounds per hour based on a daily average.

TAPCR 1200-03-07-.07(2)

Compliance with this requirement shall be assured by operating the diesel generator as designed and complying with condition 3.

8. Visible emissions from this source shall not exhibit greater than twenty percent (20%) opacity, except for one (1) six-minute period per one (1) hour period and for no more than four (4) six-minute periods in any twenty-four (24) hour period. Visible emissions from this source shall be determined by EPA Method 9, as published in the current 40 CFR 60, Appendix A (six-minute average).

TAPCR 1200-03-05-.01(1) and 1200-03-05-.03(6)

9. The following annual emissions are based on a total of 600 hours of operation (100 non-emergency and 500 emergency hours), these emission totals will be used to calculate annual emission fees:

Annual Emissions for Fees (tons per year)			
PM	SO ₂	NO _x	VOC
0.17	0.08	1.22	0.10

TAPCR 1200-03-26-.02(6)

10. Record keeping requirements for this source, including all data and calculations, must be updated and maintained based on the following schedule:

Record Keeping Type

Update Requirement

Monthly Log

Recorded within 30 days after the end of the month

Weekly Log

Recorded within 7 days after the end of the week

Daily Log

Recorded within 7 days after the end of the day

TAPCR 1200-03-09

11. The permittee shall comply with all applicable federal and state regulations concerning the operation of this source. This includes but is not limited to, federal regulations published under 40 CFR part 63 for sources of hazardous air pollutants and 40 CFR part 60, New Source Performance Standards.

This source shall operate in accordance with the terms of this permit and the information submitted in the approved permit application.

TAPCR 1200-03-09-.03(8)

NESHAP (National Emission Standards for Hazardous Air Pollutants) Stationary RICE (reciprocating internal combustion engines)

40 CFR Part 63 Subpart ZZZZ: National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

12. A new stationary RICE located at an area source must meet the requirements of 40 CFR part 63 subpart ZZZZ by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines. No further requirements apply for such engines under 40 CFR part 63 subpart ZZZZ.

40 CFR §63.6590(c)

40 CFR Part 60: Standards of Performance for New Stationary Sources (NSPS)

40 CFR Part 60 Subpart III: Standards of Performance for Stationary Compression Ignition (CI) Internal Combustion Engines (ICE)

13. Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new non-road CI engines in 40 CFR §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

40 CFR §60.4205 (b)

14. Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in the following paragraph:

For engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new non-road CI engines for the same model year and maximum engine power in 40 CFR §89.112 and 40 CFR §89.113 for all pollutants beginning in model year 2007.

40 CFR §60.4202(a)(2)

15. Beginning October 1, 2010, owners and operators of stationary CI ICE subject to 40 CFR part 60 subpart III with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR §80.510(b) for non-road diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.

40 CFR §60.4207(b)

16. If you are an owner or operator and must comply with the emission standards specified in 40 CFR part 60 subpart III, you must do all of the following, except as permitted in condition 18.

Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions,

Change only those emission-related settings that are permitted by the manufacture, and

Meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.

40 CFR §60.4211(a)

17. If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (1) through (3) of this condition. In order for the engine to be considered an emergency stationary ICE under 40 CFR part 60 subpart III, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (1) through (3) of this condition, is prohibited. If you do not operate the engine according to the requirements in paragraphs (1) through (3) of this condition, the engine will not be considered an emergency engine under 40 CFR part 60 subpart III and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary ICE in emergency situations.

(2) You may operate your emergency stationary ICE for any combination of the purposes specified in paragraphs (2)(i) through (iii) of this condition for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (3) of this condition counts as part of the 100 hours per calendar year allowed by this paragraph.

(2)(i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Technical Secretary for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.

(2)(ii) Emergency stationary ICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see 40 CFR §60.17), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.

(2)(iii) Emergency stationary ICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.

(3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (2) of this condition. Except as provided in paragraph (3)(i) of this condition, the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(3)(i) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

40 CFR §60.4211(f)

18. If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer, you must demonstrate compliance as follows:

If you are an owner or operator of a stationary CI internal combustion engine greater than or equal to 100 HP and less than or equal to 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.

40 CFR §60.4211(g)

19. If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 of 40 CFR part 60 subpart IIII, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

40 CFR §60.4214(b)

State Requirements

20. This permit shall serve as a temporary operating permit from initial start-up to the receipt of a standard operating permit, provided the operating permit is applied for within thirty (30) days of initial start-up and the conditions of this permit and any applicable emission standards are met.

TAPCR 1200-03-09


21. The permittee shall certify the start-up date of the air contaminant source regulated by this permit by submitting

A COPY OF ALL PAGES OF THIS PERMIT,
with the information required in A) and B) of this condition completed, to the Technical Secretary's
representatives listed below:

- A) DATE OF START-UP: 05/31/2013
month day year
- B) Anticipated operating rate: Emergency Backup Generator
percent of maximum rated capacity

For the purpose of complying with this condition, "start-up" of the air contaminant source shall be the date of the setting in operation of the source for the production of product for sale or use as raw materials or steam, heat, or electrical production.

The undersigned represents that he/she has the full authority to represent and bind the permittee in environmental permitting affairs. The undersigned further represents that the above provided information is true to the best of his/her knowledge and belief.

Signature 		Date <u>6/28/2013</u>
Signer's name (type or print) <u>Scott Sandefur</u>	Title <u>Director ETP&S</u>	Phone (with area code) <u>602-284-0280</u>

Note: This certification is not an application for an operating permit. At a minimum, the appropriate application form(s) must be submitted requesting an operating permit. The application must be submitted in accordance with the requirements of this permit.

The completed certification(s) shall be delivered to the East Tennessee Permit Program and the Environmental Field Office at the addresses listed below, no later than thirty (30) days after the emission unit(s) are started-up.

East Tennessee Permit Program &
Division of Air Pollution Control
9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
TAPCR 1200-03-09

Knoxville Environmental Field Office
Division of Air Pollution Control
3711 Middlebrook Pike
Knoxville, TN 37921

(end of conditions)

The permit application gives the location of this source as 35.84969 Latitude and -83.78735 Longitude.