

November 22, 2021

Ms. Michelle Walker Owenby, Director
Division of Air Pollution Control
Tennessee Department of Environment and Conservation
William R. Snodgrass Tennessee Tower, 15th Floor
312 Rosa L. Parks Avenue
Nashville, TN 37243
Air.Pollution.Control@TN.gov

RE: East Tennessee Natural Gas, LLC Station 3110 - Wartburg Compressor Station, 65-0028/979102 Title V Permit Renewal Application – Agreement Letter

Dear Ms. Owenby:

East Tennessee Natural Gas, LLC (ETNG) is applying for a construction permit for three natural gas-fired combustion turbines and a natural gas-fired reciprocating engine (the sources) at the ETNG's Station 110 - Wartburg (the Facility) located in Wartburg, Morgan County, Tennessee. In order to reduce annual emission fees, we agree to be bound by a permit requiring the facility to:

- 1. Use only natural gas as a fuel for the source. To demonstrate compliance, the Facility will maintain documentation to demonstrate the type(s) of fuel used by the sources. Documentation shall include, but is not limited to, manufacturer's specifications, purchase records, operating manuals, or a tag affixed to the unit by the manufacturer. These documents shall be kept readily available/accessible and made available upon request by the Technical Secretary or a Division representative.
- 2. Limit emissions of particulate matter from the combustion turbines to no more than 0.36 pounds per hour (lbs/hr) on a daily average basis. Compliance with this emission limitation is assured by the combustion turbines heat input rating, the use of natural gas as fuel, and the emission factor of 6.60 E-03 pounds per million Btu from Table 3.1-2a of AP-42, Chapter 3, Section 1, Stationary Gas Turbines, supplement to 5th Ed. dated 4/00.

Should the facility need to increase any limit above, ETNG will apply for and receive a construction permit or Title V modification in accordance with TAPCR 1200-03-09-.01 or TAPCR 1200-03-09-.02(11)(d)1(i)(V) prior to making the change.

If you have any questions or comments about the information presented in this letter, please do not hesitate to contact Mr. Bobby Van Borssum at (713) 627-4257 or Bobby. Van Borssum@enbridge.com.

Sincerely,

EAST TENNESSEE NATURAL GAS, LLC

Robert Arnold

Director, Field Operations Central Region