



**CONSTRUCTION PERMIT APPLICATION
(including Greenhouse Gas Emissions Evaluation)**

**LaFollette Medical Center
Emission Source 07-0027-01
LaFollette, Tennessee**

AMEC Project No. 568460000

Submitted to:

**Tennessee Division of Air Pollution Control
9th Floor, L&C Annex
401 Church Street
Nashville, Tennessee 37243-1531**

Prepared by:

**AMEC Environment & Infrastructure, Inc.
3800 Ezell Road, Suite 100
Nashville, Tennessee 37211**

January 23, 2012



January 23, 2012

Mr. Barry Stephens, P.E. Division Director
Tennessee Division of Air Pollution Control
9th Floor, L&C Annex
401 Church Street
Nashville, Tennessee 37243-1531

ATTN: Hymelia Craig

**RE: Construction Permit Application Package including
Greenhouse Gas Emissions Evaluation
LaFollette Medical Center
Emission Source 07-0027-01
LaFollette, TN
AMEC Project No. 568460000**

RECEIVED

2012 FEB -7 AM 10:01

TN DIV OF
AIR POLLUTION CONTROL

Dear Ms. Craig:

AMEC Environment & Infrastructure, Inc. (AMEC) is submitting the enclosed permit application on behalf of the LaFollette Medical Center in LaFollette, Tennessee. This facility, identified as Emission Source No. 07-0027-01, was previously known as the St. Mary's Medical Center of Campbell County, but has recently undergone a name change to the LaFollette Medical Center.

The facility's permit, Permit Number 009562F, was issued in May of 1980 for four boilers present at the medical center. A recent review of the facility's records at the Tennessee Division of Air Pollution Control (TDAPC) offices in Nashville, indicated that historical documentation for the facility is limited and it is possible that the appropriate paperwork was not filed for the replacement of three of the boilers. In addition, two emergency generators have also been added to the facility. Therefore, at this time we are submitting a construction permit application with the appropriate TDAPC forms for the emission units present at the LaFollette Medical Center.

In support of the information needed on the TDAPC forms and to start a clear record of the units present at the facility, we have restructured the emission point numbering system. The combustion units currently present at the facility, each with a separate exhaust stack, are re-numbered below with the year of construction noted in parentheses:

- No. 10 - Kewanee Low Pressure Boiler (1977);
- No. 11 - John Deere Emergency Generator (1996);
- No. 12 - Superior Boiler (1999);
- No. 13 - Caterpillar Emergency Generator (2003);
- No. 14 - BP Boiler (2005); and
- No. 15 - Cleaver Brooks Boiler (2009).

AMEC Environment & Infrastructure, Inc.
3800 Ezell Road, Ste. 100
Nashville, TN
USA 37211
Tel 1+(615) 333-0630
Fax 1+(615) 781-0655

www.amec.com



The permit application package also includes an evaluation of maximum potential to emit (PTE) and estimated average emissions for both criteria air pollutants and greenhouse gases. The average emissions are based on facility emissions in 2010. Greenhouse gas (GHG) emissions in tons per year are expressed as carbon dioxide equivalents (CO₂e).

Pursuant to guidance provided by TDAPC, the GHG emissions associated with each permitted and insignificant emission source at the facility were calculated using the U.S. Environmental Protection Agency (USEPA) default emission factors. Emissions were estimated for the individual GHG pollutants, including carbon dioxide (CO₂), nitrous oxide (N₂O), and methane (CH₄). Emissions were initially presented in metric tons, and then summed and converted to short tons. Hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF₆) substances are not known to be used at the facility, and thus there are no known emissions of these substances.

The maximum PTE for nitrogen oxides (NO_x) for the emission units at the facility is over 10 tons per year. Based on this emission rate and the TDAPC Schedule A for Construction Permit Fees, the fee for this construction permit application is \$500, which is also enclosed.

If you have any questions regarding this information, please contact Mr. Charles Johnson of the LaFollette Medical Center at (423) 907-1651 or Ms. Sara Mathews of AMEC Environment and Infrastructure, Inc. at (615) 333-0630.

Sincerely,
AMEC Environment & Infrastructure, Inc.

A handwritten signature in blue ink that reads "Kathleen D. Regan".

Kathleen D. Regan
Principal Engineer
email: kathleen.regan@amec.com

A handwritten signature in blue ink that reads "Sara B. Mathews".

Sara B. Mathews
Senior Environmental Scientist
email: sara.mathews@amec.com

Enclosure 1 – TDAPC Forms and Emissions Evaluation

Enclosure 2 – TDAPC Fee Payment

cc: Mr. Charles E. Johnson, LaFollette Medical Center

Enclosure 1

TDAPC Forms and Emissions Evaluation

List of Forms

Form	Form Name	Page
APC20	Permit Application	2 pages total
APC21	Process or Fuel Burning Source Description	2 pages for each unit
APC 22	Emission Point Description	2 pages for each unit
APC Attachment	Emissions Estimates	1 page for each unit
Attachment APC 22	GHG Emissions	3 pages total

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF AIR POLLUTION CONTROL



TN. DIV. OF
AIR POLLUTION CONTROL

2012 FEB -7 AM 10: 02

9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone: (615) 532-0554
FAX: (615) 532-0614

NOT TO BE USED FOR TITLE V APPLICATIONS

**PROCESS OR FUEL BURNING
SOURCE DESCRIPTION**

APC21(& 24)

PLEASE TYPE OR PRINT, SUBMIT IN DUPLICATE AND ATTACH TO THE PERMIT APPLICATION.

1. ORGANIZATION NAME LaFollette Medical Center		/// FOR	APC COMPANY-POINT NO.
2. EMISSION SOURCE NO. (AS ON PERMIT APPLICATION) 07-0027-01	SIC CODE 801102	/// APC	APC PERMIT/LOG NO.
3. DESCRIPTION OF PROCESS OR FUEL BURNING UNIT John Deere Emergency Generator, 180 kW			

4. NORMAL OPERATION: →	HOURS/DAY 5	DAYS/WEEK 2	WEEKS/YEAR 52	DAYS/YEAR
5. PERCENT ANNUAL THROUGHPUT: →	DEC.-FEB. 25%	MARCH-MAY 25%	JUNE-AUG. 25%	SEPT.-NOV. 25%
6. TYPE OF PERMIT APPLICATION				(CHECK BELOW ONE ONLY)
PROCESS SOURCE: APPLY FOR A SEPARATE PERMIT FOR EACH SOURCE. (CHECK AT RIGHT, AND COMPLETE LINES 7, 8, 13, AND 14).				()
PROCESS SOURCE WITH IN-PROCESS FUEL: PRODUCTS OF COMBUSTION CONTACT MATERIALS HEATED. APPLY FOR A SEPARATE PERMIT FOR EACH SOURCE. (CHECK AT RIGHT, AND COMPLETE LINES 7, 8, AND 10 THROUGH 14)				()
NON-PROCESS FUEL BURNING SOURCE: PRODUCTS OF COMBUSTION DO NOT CONTACT MATERIALS HEATED. COMPLETE THIS FORM FOR EACH BOILER OR FUEL BURNER AND COMPLETE AN EMISSION POINT DESCRIPTION FORM (APC 22) FOR EACH STACK. (CHECK AT RIGHT, AND COMPLETE LINES 9 TO 14)				(X)
7. TYPE OF OPERATION: CONTINUOUS, ()		BATCH ()	NORMAL BATCH TIME	NORMAL BATCHES/DAY
8. PROCESS MATERIAL INPUTS AND IN-PROCESS SOLID FUELS	DIAGRAM* REFERENCE	INPUT RATES (POUNDS/HOUR) DESIGN ACTUAL		(FOR APC USE ONLY) SCC CODE
A.				/
B.				/
C.				/
D.				/
E.				/
F.				/
G.				/
TOTALS				/

* A SIMPLE PROCESS FLOW DIAGRAM MUST BE ATTACHED.

(OVER)

9. BOILER OR BURNER DATA: (COMPLETE LINES 9 TO 14 USING A SEPARATE FORM FOR EACH BOILER)

BOILER NUMBER 11	STACK NUMBER** 11	TYPE OF FIRING*** oil burner	RATED BOILER HORSEPOWER	RATED INPUT CAPACITY (10 ⁶ BTU/HR) 1.69	OTHER BOILER RATING (SPECIFY CAPACITY AND UNITS)
BOILER SERIAL NO. 358450		DATE CONSTRUCTED 1996	DATE OF LAST MODIFICATION (EXPLAIN IN COMMENTS BELOW).		

** BOILERS WITH A COMMON STACK WILL HAVE THE SAME STACK NUMBER.

*** CYCLONE, SPREADER (WITH OR WITHOUT REINJECTION), PULVERIZED (WET OR DRY BOTTOM, WITH OR WITHOUT REINJECTION), OTHER STOKER (SPECIFY TYPE), HAND FIRED, AUTOMATIC, OR OTHER TYPE (DESCRIBE BELOW IN COMMENTS).

10. FUEL DATA: (COMPLETE FOR A PROCESS SOURCE WITH IN-PROCESS FUEL OR A NON-PROCESS FUEL BURNING SOURCE)

PRIMARY FUEL TYPE (SPECIFY) Natural Gas and/or Fuel Oil #2				STANDBY FUEL TYPE(S) (SPECIFY)			
FUELS USED	ANNUAL USAGE	HOURLY USAGE		% SULFUR	% ASH	BTU VALUE OF FUEL	(FOR APC ONLY) SCC CODE
		DESIGN	AVERAGE				
NATURAL GAS:	10 ⁶ CUFT	CUFT	CUFT			1,000	
#2 FUEL OIL:	10 ³ GAL 6.05	GAL 12.1	GAL 12.1	0.0015%	NA	140,000	
#5 FUEL OIL:	10 ³ GAL	GAL	GAL		/ / / /		
#6 FUEL OIL:	10 ³ GAL	GAL	GAL		/ / / /		
COAL:	TONS	LBS	LBS				
WOOD:	TONS	LBS	LBS	/ / / / / / / /	/ / / /		
LIQUID PROPANE:	10 ³ GAL	GAL	GAL	/ / / / / / / /	/ / / /	85,000	
OTHER (.SPECIFY TYPE & UNITS.):							

11. IF WOOD IS USED AS A FUEL, SPECIFY TYPES AND ESTIMATE PERCENT BY WEIGHT OF BARK
NA12. IF WOOD IS USED WITH OTHER FUELS, SPECIFY PERCENT BY WEIGHT OF WOOD CHARGED TO THE BURNER.
NA**13. COMMENTS**

Emergency generator is assumed to have the maximum potential to operate 500 hours per year.

No information currently available to adjust maximum hourly usage to represent an average hourly usage in gallons per hour.

14. SIGNATURE


DATE

1/24/12



NOT TO BE USED FOR TITLE V APPLICATIONS

EMISSION POINT DESCRIPTION

APC 22

PLEASE TYPE OR PRINT AND SUBMIT IN DUPLICATE FOR EACH STACK OR EMISSION POINT.
ATTACH TO THE PERMIT APPLICATION.

1. ORGANIZATION NAME LaFollette Medical Center				///	APC COMPANY POINT NO.
2. EMISSION SOURCE NO. (FROM APPLICATION) 07-0027-01				FOR	
2. EMISSION SOURCE NO. (FROM APPLICATION) 07-0027-01				APC	APC SEQUENCE NO.
3. LOCATION:	LATITUDE N36°23.330'	LONGITUDE W84°6.651	UTM VERTICAL	UTM HORIZONTAL	
4. BRIEF EMISSION POINT DESCRIPTION (ATTACH A SKETCH IF APPROPRIATE): John Deere Emergency Generator, 180 kW					DISTANCE TO NEAREST PROPERTY LINE (FT) 200

COMPLETE LINES 5 AND 6 IF DIFFERENT FROM THAT ON THE PROCESS OR FUEL BURNING SOURCE DESCRIPTION (APC 21)

5. NORMAL OPERATION:	HOURS/DAY	DAYS/WEEK	WEEK/YEAR	DAYS/YEAR			
6. PERCENT ANNUAL THROUGHPUT:	DEC.-FEB.	MARCH-MAY	JUNE-AUG.	SEPT.-NOV.			
7. STACK OR EMISSION POINT DATA:	HEIGHT ABOVE GRADE (FT) 9 ft	DIAMETER (FT) 6"	TEMPERATURE (°F) 450-500	% OF TIME OVER 125°F 100%	DIRECTION OF EXIT (UP, DOWN OR HORIZONTAL) Horizontal		
DATA AT EXIT CONDITIONS:	FLOW (ACTUAL FT ³ /MIN.) NA	VELOCITY (FT/SEC) NA	MOISTURE (GRAINS/FT ³) NA	MOISTURE (PERCENT) NA			
DATA AT STANDARD CONDITIONS:	FLOW (DRY STD. FT ³ /MIN) NA	VELOCITY (FT/SEC) NA	MOISTURE (GRAINS/FT ³) NA	MOISTURE (PERCENT) NA			
8. AIR CONTAMINANTS	ACTUAL EMISSIONS				EMISSIONS* EST.	CONTROL DEVICES*	CONTROL EFFICIENCY%
	EMISSIONS (LBS/HR) AVERAGE	EMISSIONS (LBS/HR) MAXIMUM	CONCENTRATION	AVG. EMISSIONS (TONS/YR)			
PARTICULATES	0.53	0.53	**	0.018	3		
SULFUR DIOXIDE	0.49	0.49	***	0.016	3		
CARBON MONOXIDE	1.61	1.61	PPM	0.053	3		
ORGANIC COMPOUNDS	0.55	0.55	PPM	0.018	3		
NITROGEN OXIDES	7.48	7.48	PPM	0.25	3		
FLUORIDES							
OTHER(SPECIFY) GHG emissions				9.12 short tons	5		
OTHER(SPECIFY)							

(OVER)

9. CHECK TYPES OF MONITORING AND RECORDING INSTRUMENTS THAT ARE ATTACHED:OPACITY MONITOR (), SO₂ MONITOR (), NO_x MONITOR (), OTHER (SPECIFY IN COMMENTS) () Not Applicable**10. COMMENTS****11. SIGNATURE****DATE**

1/24/12

* REFER TO THE BACK OF THE PERMIT APPLICATION FORM FOR ESTIMATION METHOD AND CONTROL DEVICE CODES.

** EXIT GAS PARTICULATE CONCENTRATION UNITS: PROCESS — GRAINS/DRY STANDARD FT³ (70°F); WOOD FIRED BOILERS — GRAINS/DRY STANDARD FT³ (70°F); ALL OTHER BOILERS — LBS/MILLION BTU HEAT INPUT.

*** EXIT GAS SULFUR DIOXIDE CONCENTRATIONS UNITS: PROCESS — PPM BY VOLUME, DRY BASES; BOILERS — LBS/MILLION BTU HEAT INPUT.

APC 22 Attachment - Emission Source 07-0027-01
Calculation of Emissions for John Deere Emergency Generator - 180 kW; 1.69 MMBTU/hr
LaFollette Medical Center, LaFollette, TN

Unit	Generator Rating		Heat Input	Run Time (1)	Annual Power Output		Annual Heat Input
	(kw)	(hp)	(MMBTu/hr)	(hr/yr)	(Kw-hr/yr)	(hp-hr/yr)	(MMBTu/yr)
Emergency Generator	180	241.38	1.68966	500	90000	120690	844.83

(1) No operating limit for emergency generators used under emergency situations; assumed 500 hour/year for emissions
Average usage is approximately 66 hours per year.

Calculation of Unit Rating

Unit rating (kw) x 1.341 (hp/kw) = Unit rating (hp)

Calculation of Heat Input

Generator Rating (kw) x 1.341 (hp/kw) x 7000 (BTU/hp-hr) / 1,000,000 (BTU/MMBTu) = Heat Input (MMBTu/hr)

Note: The emission factors in AP-42 take into account the approximately 35% efficiency of internal combustion engines.

Emissions Evaluation

Constituent	Source	Emission Factor (lb/hp-hr)	Emissions (lb/hr)	Emissions (lb/year)	Emissions (tons/year)
NOx	AP-42	0.03100	7.48	3741.39	1.87
CO	AP-42	0.00668	1.61	806.21	0.403
TOC	AP-42	0.00251	0.61	302.93	0.151
Nonmethane HC (VOC)	AP-42	0.00228	0.55	275.67	0.138
PM10 (TSP)	AP-42	0.00220	0.53	265.52	0.133
SO2	AP-42	0.00205	0.49	247.41	0.124

Conversion factors: 0.002205 lb/gram
0.0005 tons/lb

Notes:

Assumes VOCs represent 91% of total organic carbon emissions.

AP-42 Chapter 3.3, 10/96.

Average Evaluation - 66 hours/year
Calculation of Emissions for John Deere Emergency Generator - 180 kW; 1.69 MMBTU/hr
LaFollette Medical Center, LaFollette, TN

Unit	Generator Rating		Heat Input	Run Time (1)	Annual Power Output		Annual Heat Input
	(kw)	(hp)	(MMBTu/hr)	(hr/yr)	(Kw-hr/yr)	(hp-hr/yr)	(MMBTu/yr)
Emergency Generator	180	241.38	1.68966	66	11880	15931.08	111.51756

(1) No operating limit for emergency generators used under emergency situations; assumed 500 hour/year for emissions
Average usage is approximately 66 hours per year.

Calculation of Unit Rating

Unit rating (kw) x 1.341 (hp/kw) = Unit rating (hp)

Calculation of Heat Input

Generator Rating (kw) x 1.341 (hp/kw) x 7000 (BTU/hp-hr) / 1,000,000 (BTU/MMBTu) = Heat Input (MMBTu/hr)

Note: The emission factors in AP-42 take into account the approximately 35% efficiency of internal combustion engines.

Emissions Evaluation

Constituent	Source	Emission Factor (lb/hp-hr)	Emissions (lb/hr)	Emissions (lb/year)	Emissions (tons/year)
NOx	AP-42	0.03100	7.48	493.86	0.25
CO	AP-42	0.00668	1.61	106.42	0.053
TOC	AP-42	0.00251	0.61	39.99	0.020
Nonmethane HC (VOC)	AP-42	0.00228	0.55	36.39	0.018
PM10 (TSP)	AP-42	0.00220	0.53	35.05	0.018
SO2	AP-42	0.00205	0.49	32.66	0.016

Conversion factors: 0.002205 lb/gram
0.0005 tons/lb

Notes:

Assumes VOCs represent 91% of total organic carbon emissions.

AP-42 Chapter 3.3, 10/96.



TN. DIV. OF
AIR POLLUTION CONTROL
9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone: (615) 532-0554
FAX: (615) 532-0614
2012 FEB -7 AM 10:10

NOT TO BE USED FOR TITLE V APPLICATIONS

PROCESS OR FUEL BURNING SOURCE DESCRIPTION

APC21(& 24)

PLEASE TYPE OR PRINT, SUBMIT IN DUPLICATE AND ATTACH TO THE PERMIT APPLICATION.

RECEIVED

1. ORGANIZATION NAME LaFollette Medical Center		/// FOR	APC COMPANY-POINT NO.	
2. EMISSION SOURCE NO. (AS ON PERMIT APPLICATION) 07-0027-01		SIC CODE 801102	/// APC	APC PERMIT/LOG NO.
3. DESCRIPTION OF PROCESS OR FUEL BURNING UNIT Caterpillar Emergency Generator, 800 kW				
4. NORMAL OPERATION: →	HOURS/DAY 5	DAYS/WEEK 2	WEEKS/YEAR 52	DAYS/YEAR
5. PERCENT ANNUAL THROUGHPUT: →	DEC.-FEB. 25%	MARCH-MAY 25%	JUNE-AUG. 25%	SEPT.-NOV. 25%
6. TYPE OF PERMIT APPLICATION				(CHECK BELOW ONE ONLY)
PROCESS SOURCE: APPLY FOR A SEPARATE PERMIT FOR EACH SOURCE. (CHECK AT RIGHT, AND COMPLETE LINES 7, 8, 13, AND 14).				()
PROCESS SOURCE WITH IN-PROCESS FUEL: PRODUCTS OF COMBUSTION CONTACT MATERIALS HEATED. APPLY FOR A SEPARATE PERMIT FOR EACH SOURCE. (CHECK AT RIGHT, AND COMPLETE LINES 7, 8, AND 10 THROUGH 14)				()
NON-PROCESS FUEL BURNING SOURCE: PRODUCTS OF COMBUSTION DO NOT CONTACT MATERIALS HEATED. COMPLETE THIS FORM FOR EACH BOILER OR FUEL BURNER AND COMPLETE AN EMISSION POINT DESCRIPTION FORM (APC 22) FOR EACH STACK. (CHECK AT RIGHT, AND COMPLETE LINES 9 TO 14)				(X)
7. TYPE OF OPERATION: CONTINUOUS, ()		BATCH ()	NORMAL BATCH TIME	NORMAL BATCHES/DAY
8. PROCESS MATERIAL INPUTS AND IN-PROCESS SOLID FUELS	DIAGRAM* REFERENCE	INPUT RATES (POUNDS/HOUR) DESIGN ACTUAL		(FOR APC USE ONLY) SCC CODE
A.				/
B.				/
C.				/
D.				/
E.				/
F.				/
G.				/
TOTALS				/

* A SIMPLE PROCESS FLOW DIAGRAM MUST BE ATTACHED.

(OVER)

9. BOILER OR BURNER DATA: (COMPLETE LINES 9 TO 14 USING A SEPARATE FORM FOR EACH BOILER)

BOILER NUMBER 13	STACK NUMBER** 13	TYPE OF FIRING*** oil burner	RATED BOILER HORSEPOWER	RATED INPUT CAPACITY (10 ⁶ BTU/HR) 7.5	OTHER BOILER RATING (SPECIFY CAPACITY AND UNITS)
BOILER SERIAL NO. 3FZ04531		DATE CONSTRUCTED 2003	DATE OF LAST MODIFICATION (EXPLAIN IN COMMENTS BELOW).		

** BOILERS WITH A COMMON STACK WILL HAVE THE SAME STACK NUMBER.

*** CYCLONE, SPREADER (WITH OR WITHOUT REINJECTION), PULVERIZED (WET OR DRY BOTTOM, WITH OR WITHOUT REINJECTION), OTHER STOKER (SPECIFY TYPE), HAND FIRED, AUTOMATIC, OR OTHER TYPE (DESCRIBE BELOW IN COMMENTS).

10. FUEL DATA: (COMPLETE FOR A PROCESS SOURCE WITH IN-PROCESS FUEL OR A NON-PROCESS FUEL BURNING SOURCE)

PRIMARY FUEL TYPE (SPECIFY) Natural Gas and/or Fuel Oil #2				STANDBY FUEL TYPE(S) (SPECIFY)			
FUELS USED	ANNUAL USAGE	HOURLY USAGE		% SULFUR	% ASH	BTU VALUE OF FUEL	(FOR APC ONLY) SCC CODE
		DESIGN	AVERAGE				
NATURAL GAS:	10 ⁶ CUFT	CUFT	CUFT			1,000	
#2 FUEL OIL:	10 ³ GAL 26.79	GAL 53.57	GAL 53.57	0.0015%	NA	140,000	
#5 FUEL OIL:	10 ³ GAL	GAL	GAL		/ / / / / /		
#6 FUEL OIL:	10 ³ GAL	GAL	GAL		/ / / / / /		
COAL:	TONS	LBS	LBS				
WOOD:	TONS	LBS	LBS	/ / / / / / / / / /	/ / / / / /		
LIQUID PROPANE:	10 ³ GAL	GAL	GAL	/ / / / / / / / / /	/ / / / / /	85,000	
OTHER (.SPECIFY TYPE & UNITS.):							

11. IF WOOD IS USED AS A FUEL, SPECIFY TYPES AND ESTIMATE PERCENT BY WEIGHT OF BARK
NA12. IF WOOD IS USED WITH OTHER FUELS, SPECIFY PERCENT BY WEIGHT OF WOOD CHARGED TO THE BURNER.
NA**13. COMMENTS**

Emergency generator is assumed to have the maximum potential to operate 500 hours per year.

No information currently available to adjust maximum hourly usage to represent an average hourly usage in gallons per hour.

14. SIGNATURE


DATE

1/24/12



TN. DIV. OF
AIR POLLUTION CONTROL

2012 FEB -7 AM 10:12

9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone: (615) 532-0554
FAX: (615) 532-0614

NOT TO BE USED FOR TITLE V APPLICATIONS

EMISSION POINT DESCRIPTION

APC 22

PLEASE TYPE OR PRINT AND SUBMIT IN DUPLICATE FOR EACH STACK OR EMISSION POINT.
ATTACH TO THE PERMIT APPLICATION.

1. ORGANIZATION NAME LaFollette Medical Center				///	APC COMPANY POINT NO.
2. EMISSION SOURCE NO. (FROM APPLICATION) 07-0027-01				FOR	APC SEQUENCE NO.
FLOW DIAGRAM POINT NUMBER 13				APC	
3. LOCATION:	LATITUDE N36°23.320	LONGITUDE W84°6.725	UTM VERTICAL		UTM HORIZONTAL
4. BRIEF EMISSION POINT DESCRIPTION (ATTACH A SKETCH IF APPROPRIATE): Caterpillar Emergency Generator, 800 kW					DISTANCE TO NEAREST PROPERTY LINE (FT) 130

COMPLETE LINES 5 AND 6 IF DIFFERENT FROM THAT ON THE PROCESS OR FUEL BURNING SOURCE DESCRIPTION (APC 21)

5. NORMAL OPERATION:	HOURS/DAY	DAYS/WEEK	WEEK/YEAR		DAYS/YEAR		
6. PERCENT ANNUAL THROUGHPUT:	DEC.-FEB.	MARCH-MAY	JUNE-AUG.		SEPT.-NOV.		
7. STACK OR EMISSION POINT DATA:	HEIGHT ABOVE GRADE (FT) 9	DIAMETER (FT) 6"	TEMPERATURE (°F) 262-972	% OF TIME OVER 125°F 100%	DIRECTION OF EXIT (UP, DOWN OR HORIZONTAL) Horizontal		
DATA AT EXIT CONDITIONS:	FLOW (ACTUAL FT³/MIN.) NA	VELOCITY (FT/SEC) NA	MOISTURE (GRAINS/FT³) NA		MOISTURE (PERCENT) NA		
DATA AT STANDARD CONDITIONS:	FLOW (DRY STD. FT³/MIN) NA	VELOCITY (FT/SEC) NA	MOISTURE (GRAINS/FT³) NA		MOISTURE (PERCENT) NA		
8. AIR CONTAMINANTS	ACTUAL EMISSIONS				EMISSIONS* EST.	CONTROL DEVICES*	CONTROL EFFICIENCY%
	EMISSIONS (LBS/HR)		CONCENTRATION	AVG. EMISSIONS (TONS/YR)			
	AVERAGE	MAXIMUM					
PARTICULATES	0.75	0.75	**	0.014	3		
SULFUR DIOXIDE	0.01	0.01	***	0.00023	3		
CARBON MONOXIDE	5.90	5.90	PPM	0.11	3		
ORGANIC COMPOUNDS	0.69	0.69	PPM	0.012	3		
NITROGEN OXIDES	25.75	25.75	PPM	0.46	3		
FLUORIDES							
OTHER(SPECIFY) GHG Emissions				22.11 short tons	5		
OTHER(SPECIFY)							

(OVER)

9. CHECK TYPES OF MONITORING AND RECORDING INSTRUMENTS THAT ARE ATTACHED:OPACITY MONITOR (), SO₂ MONITOR (), NO_x MONITOR (), OTHER (SPECIFY IN COMMENTS) () Not Applicable**10. COMMENTS****11. SIGNATURE****DATE**

1/24/12

* REFER TO THE BACK OF THE PERMIT APPLICATION FORM FOR ESTIMATION METHOD AND CONTROL DEVICE CODES.

** EXIT GAS PARTICULATE CONCENTRATION UNITS: PROCESS — GRAINS/DRY STANDARD FT³ (70°F); WOOD FIRED BOILERS — GRAINS/DRY STANDARD FT³ (70°F); ALL OTHER BOILERS — LBS/MILLION BTU HEAT INPUT.

*** EXIT GAS SULFUR DIOXIDE CONCENTRATIONS UNITS: PROCESS — PPM BY VOLUME, DRY BASES; BOILERS — LBS/MILLION BTU HEAT INPUT.

APC 22 Attachment - Emission Source 07-0027-01
Calculation of Emissions for Caterpillar Emergency Generator - 800 kW; 7.5 MMBTU/hr
LaFollette Medical Center, LaFollette, TN

Unit	Generator Rating (kw)	Generator Rating (hp)	Heat Input (MMBtu/hr)	Run Time (1) (hr/yr)	Annual Power Output (Kw-hr/yr)	Annual Power Output (hp-hr/yr)	Annual Heat Input (MMBtu/yr)
Emergency Generator	800	1072.8	7.5096	500	400000	536400	3754.8

(1) No operating limit for emergency generators used under emergency situations; assumed 500 hour/year for emissions
Average usage is approximately 36 hours per year.

Calculation of Unit Rating

Unit rating (kw) x 1.341 (hp/kw) = Unit rating (hp)

Calculation of Heat Input

Generator Rating (kw) x 1.341 (hp/kw) x 7000 (BTU/hp-hr) / 1,000,000 (BTU/MMBtu) = Heat Input (MMBtu/hr)

Note: The emission factors in AP-42 take into account the approximately 35% efficiency of internal combustion engines.

Emissions Evaluation

Constituent	Source	Emission Factor (lb/hp-hr)	Emissions (lb/hr)	Emissions (lb/year)	Emissions (tons/year)
NOx	AP-42	0.02400	25.75	12873.60	6.44
CO	AP-42	0.00550	5.90	2950.20	1.475
HC	AP-42	0.00071	0.76	378.16	0.189
Nonmethane HC (VOC)	AP-42	0.00064	0.69	344.13	0.172
PM	AP-42	0.00070	0.75	375.48	0.188
SO2	AP-42	1.2135E-05	0.01	6.51	0.003

Conversion factors: 0.002205 lb/gram
0.0005 tons/lb

Notes:

Based on AP-42, assumes VOCs represent 91% of hydrocarbon emissions.

Assumes sulfur content of diesel fuel of 0.0015%.

AP-42 Chapter 3.4, 10/96.

Average Emissions - 36 hours/year
Calculation of Emissions for Caterpillar Emergency Generator - 800 kW; 7.5 MMBTU/hr
LaFollette Medical Center, LaFollette, TN

Unit	Generator Rating (kw)	Generator Rating (hp)	Heat Input (MMBtu/hr)	Run Time (1) (hr/yr)	Annual Power Output (Kw-hr/yr)	Annual Power Output (hp-hr/yr)	Annual Heat Input (MMBtu/yr)
Emergency Generator	800	1072.8	7.5096	36	28800	38620.8	270.3456

(1) No operating limit for emergency generators used under emergency situations; assumed 500 hour/year for emissions
Average usage is approximately 36 hours per year.

Calculation of Unit Rating

Unit rating (kw) x 1.341 (hp/kw) = Unit rating (hp)

Calculation of Heat Input

Generator Rating (kw) x 1.341 (hp/kw) x 7000 (BTU/hp-hr) / 1,000,000 (BTU/MMBtu) = Heat Input (MMBtu/hr)

Note: The emission factors in AP-42 take into account the approximately 35% efficiency of internal combustion engines.

Emissions Evaluation

Constituent	Source	Emission Factor (lb/hp-hr)	Emissions (lb/hr)	Emissions (lb/year)	Emissions (tons/year)
NOx	AP-42	0.02400	25.75	926.90	0.46
CO	AP-42	0.00550	5.90	212.41	0.106
HC	AP-42	0.00071	0.76	27.23	0.014
Nonmethane HC (VOC)	AP-42	0.00064	0.69	24.78	0.012
PM	AP-42	0.00070	0.75	27.03	0.014
SO2	AP-42	1.2135E-05	0.01	0.47	0.00023

Conversion factors: 0.002205 lb/gram
0.0005 tons/lb

Notes:

Based on AP-42, assumes VOCs represent 91% of hydrocarbon emissions.

Assumes sulfur content of diesel fuel of 0.0015%.

AP-42 Chapter 3.4, 10/96.