

FEB 26 2013

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF AIR POLLUTION CONTROL



9th Floor, L & C Annex
401 Church Street
Nashville, TN 37243-1531
Telephone: (615) 532-0554
FAX: (615) 532-0614

NOT TO BE USED FOR TITLE V APPLICATIONS

PERMIT APPLICATION

APC 20

PLEASE TYPE OR PRINT AND SUBMIT IN DUPLICATE FOR EACH EMISSION SOURCE. ATTACH APPROPRIATE SOURCE DESCRIPTION FORMS.

1. ORGANIZATION'S LEGAL NAME American Tower Corporation - East Sevierville		#308917	/// FOR	APC COMPANY--POINT NO.
2. MAILING ADDRESS (ST/RD/P.O. BOX) P.O. Box 63604			/// APC	APC LOG/PERMIT NO.
CITY Phoenix	STATE Arizona	ZIP CODE 85082	PHONE WITH AREA CODE 602-284-0280	
3. PRINCIPAL TECHNICAL CONTACT Scot Sandefur			PHONE WITH AREA CODE 602-284-0280	
4. SITE ADDRESS (ST/RD/HWY) 122 - County Garage Rd			COUNTY NAME Sevier	
CITY OR DISTANCE TO NEAREST TOWN Sevierville		ZIP CODE 37876	PHONE WITH AREA CODE 602-284-0280	
5. EMISSION SOURCE NO. (NUMBER WHICH UNIQUELY IDENTIFIES THIS SOURCE) E1		PERMIT RENEWAL YES () NO (✓)		
6. BRIEF DESCRIPTION OF EMISSION SOURCE Emergency Backup Power - Industrial generator set: 131 hp / 80 kw with 300 gallon diesel fuel belly tank.				

7. TYPE OF PERMIT REQUESTED				
CONSTRUCTION ()	STARTING DATE	COMPLETION DATE	LAST PERMIT NUMBER	EMISSION SOURCE REFERENCE NUMBER
OPERATING (X)	DATE CONSTRUCTION STARTED 11/30/12	DATE COMPLETED 2/12/13	LAST PERMIT NUMBER 946713P	EMISSION SOURCE REFERENCE NUMBER 78-0314-01
LOCATION TRANSFER ()	TRANSFER DATE		LAST PERMIT NUMBER	EMISSION SOURCE REFERENCE NUMBER
ADDRESS OF LAST LOCATION				

8. DESCRIBE CHANGES THAT HAVE BEEN MADE TO THIS EQUIPMENT OR OPERATION SINCE THE LAST CONSTRUCTION OR OPERATING PERMIT APPLICATION.

9. SIGNATURE (APPLICATION MUST BE SIGNED BEFORE IT WILL BE PROCESSED) 		DATE 2/21/13
10. SIGNER'S NAME (TYPE OR PRINT) Scot Sandefur	TITLE Director EH&S	PHONE WITH AREA CODE 602-284-0280

TENNESSEE AIR POLLUTION CONTROL BOARD
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
NASHVILLE, TENNESSEE 37243-1531



Permit to Construct or Modify an Air Contaminant Source Issued Pursuant to Tennessee Air Quality Act

Date Issued: **JAN 29 2013**

Permit Number:
966713P

Date Expires: January 1, 2014

Issued To:
American Tower Corporation
East Sevierville #308917

Installation Address:
122 County Garage Road
Sevierville

Installation Description:
Diesel fueled emergency power generator
with 80 kW engine

Emission Source Reference No.
78-0314-01
NSPS
40 CFR Part 60 Subpart IIII

The holder of this permit shall comply with the conditions contained in this permit as well as all applicable provisions of the Tennessee Air Pollution Control Regulations.

CONDITIONS:

1. The application that was utilized in the preparation of this permit is dated November 9, 2012, and signed by Mr. Scot D. Sandefur, Director, EH&S of the permitted facility. If this person terminates employment or is reassigned different duties and is no longer the responsible person to represent and bind the facility in environmental permitting affairs, the owner or operator of this air contaminant source shall notify the Technical Secretary of the change. Said notification shall be in writing and submitted within thirty (30) days of the change. The notification shall include the name and title of the new person assigned by the source owner or operator to represent and bind the facility in environmental permitting affairs. All representations, agreement to terms and conditions and covenants made by the former responsible person that were used in the establishment of limiting permit conditions on this permit will continue to be binding on the facility until such time that a revision to this permit is obtained that would change said representations, agreements and covenants.

(Conditions continued on next page)

TECHNICAL SECRETARY

No Authority is Granted by this Permit to Operate, Construct, or Maintain any Installation in Violation of any Law, Statute, Code, Ordinance, Rule, or Regulation of the State of Tennessee or any of its Political Subdivisions.

NON-TRANSFERABLE

POST AT INSTALLATION ADDRESS

2. The maximum heat input capacity for the generator shall not exceed 307,195 British Thermal Units per hour (0.31 MMBtu/hr).
3. Operating time for non-emergency operation for this source shall not exceed 100 hours per calendar year. TAPCR 1200-03-09-.03(8) and 40 CFR 60 Subpart IIII.
4. Only No. 2 diesel fuel shall be used as fuel for this source.
5. Pursuant to 40 CFR §60.4207(b), beginning **October 1, 2010**, the permittee shall use diesel fuel that meets the requirements of 40 CFR 80.510(b), as follows:
 - (1) Sulfur content shall not exceed 15 ppm maximum for nonroad diesel fuel.
 - (2) Cetane index or aromatic content, as follows:
 - (i) A minimum cetane index of 40; or
 - (ii) A maximum aromatic content of 35 volume percent.
6. Particulate matter (TSP) emitted from this source shall not exceed 0.03 pound per hour. TAPCR 1200-03-09-.03(8) and 40 CFR §60.4205(a).
7. Sulfur dioxide (SO₂) emitted from this source shall not exceed 0.50 pound per hour.

The above emission limitation is established pursuant to 1200-03-14-.01(3) of the Tennessee Air Pollution Control Regulations and the information contained in the agreement letter dated January 21, 2013, from the permittee.
8. Carbon monoxide (CO) emitted from this source shall not exceed 0.20 pound per hour. TAPCR 1200-03-09-.03(8) and 40 CFR §60.4205(a).
9. Volatile organic compounds (VOCs) emitted from this source shall not exceed 0.81 pound per hour. TAPCR 1200-03-09-.03(8) and 40 CFR §60.4205(a).
10. Nitrogen oxides (NO_x) emitted from this source shall not exceed 0.81 pound per hour. TAPCR 1200-03-09-.03(8) and 40 CFR §60.4205(a).
11. Compliance with the emission limits in **Conditions 6, 7, 8, 9, and 10** is based on compliance with **Conditions 2 and 4** of this permit; and from the actual exhaust during a 5-mode test by the manufacturer, Generac.
12. The generator shall be equipped with a non-resettable hour meter prior to startup of the engine. TAPCR 1200-03-09-.03(8) and 40 CFR 60 Subpart IIII.
13. Visible emissions from this source shall not exhibit greater than twenty percent (20%) opacity, except for one (1) six-minute period in any one (1) hour period and for no more than four (4) six-minute periods in any twenty-four (24) hour period. Visible emissions from this source shall be determined by EPA Method 9, as published in the current 40 CFR 60, Appendix A (six-minute average). TAPCR 1200-03-05-.03(6) and TAPCR 1200-03-05-.01(1)
14. Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing on such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under 40 CFR §60.4205 but not 40 CFR §60.4204, any operation other than emergency operation, and maintenance and testing as permitted in this section, is prohibited.

Conditions continued on next page

15. The permittee shall keep a log of the number of operating hours for each month and each twelve (12) consecutive month interval at this source, in a form that readily provides the information required in the following table and shows compliance with **Conditions 3 and 14**. All data, including all required calculations, must be entered in the log no later than thirty (30) days from the end of the month for which the data is required. The permittee shall retain this record at the source location for a period of not less than two (2) years and keep this record available for inspection by the Technical Secretary or their representative. TAPCR 1200-03-10-.02(2)(a).

MONTHLY/YEARLY LOG: Source 78-0314-01

Year:					
Month	Hours Per Month	Hours Per 12 Consecutive Months	Month	Hours Per Month	Hours Per 12 Consecutive Months
January			July		
February			August		
March			September		
April			October		
May			November		
June			December		

The "Hours per 12 consecutive months" values are the sum of the hours in the 11 months preceding the month just completed + the hours in the month just completed. If data is not available for the 11 months preceding the initial use of this table, this value will be equal to the hours per month. For the second month it will be the sum of the first month and the second month. Indicate in parentheses the number of months summed [i.e., 3 (2) represents 3 hours operated in 2 months].

16. This permit is valid only at this location.
17. Operating time for this source shall not exceed 500 hours per calendar year. TAPCR 1200-03-09-.03(8) and 40 CFR Part 60 Subpart IIII
18. The permittee shall operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the permittee that are approved by the engine manufacturer. In addition, the permittee may only change those settings that are permitted by the manufacturer. TAPCR 1200-03-09-.03(8) and 40 CFR §60.4211(a)

Conditions continued on next page

19. The General Provisions of 40 CFR 60 shall apply to this source as indicated in the following table. TAPCR 1200-03-09-.03(8) and 40 CFR §60.4218.

General Provisions citation	Subject of citation	Explanation
§60.1	General applicability of the General Provisions	
§60.2	Definitions	Additional terms defined in §60.4219.
§60.3	Units and abbreviations	
§60.4	Address	
§60.5	Determination of construction or modification	
§60.6	Review of plans	
§60.7	Notification and Recordkeeping	Except that §60.7 only applies as specified in §60.4214(a).
§60.8	Performance tests	Except that §60.8 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder and engines that are not certified.
§60.9	Availability of information	
§60.10	State Authority	
§60.11	Compliance with standards and maintenance requirements	Requirements are specified in subpart IIII.
§60.12	Circumvention	
§60.13	Monitoring requirements	Except that §60.13 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder.
§60.14	Modification	
§60.15	Reconstruction	
§60.16	Priority list	
§60.17	Incorporations by reference	
§60.18	General control device requirements	
§60.19	General notification and reporting requirements	

Conditions continued on next page


20. This source shall comply with all applicable state and federal air pollution regulations. This includes, but is not limited to, federal regulations published under 40 CFR 63 for sources of hazardous air pollutants and 40 CFR 60, New Source Performance Standards.
21. This source shall operate in accordance with the terms of this permit and the information submitted in the approved permit application.
22. This permit shall serve as a temporary operating permit from initial start-up to the receipt of a standard operating permit, provided the operating permit is applied for within thirty (30) days of initial start-up and the conditions of this permit and any applicable emission standards are met.
23. The permittee shall certify the start-up date of the air contaminant source regulated by this permit by submitting
 A COPY OF ALL PAGES OF THIS PERMIT,
 with the information required in A) and B) of this condition completed, to the Technical Secretary's representatives listed below:

A) DATE OF START-UP: 2 / 12 / 2013
 month day year

B) Anticipated operating rate: Emergency Backup Generator
 _____ percent of maximum rated capacity

For the purpose of complying with this condition, "start-up" of the air contaminant source shall be the date of the setting in operation of the source for the production of product for sale or use as raw materials or steam or heat production.

The undersigned represents that he/she has the full authority to represent and bind the permittee in environmental permitting affairs. The undersigned further represents that the above provided information is true to the best of his/her knowledge and belief.

Signature 		Date <u>2/21/13</u>
Signer's name (type or print) <u>Scot Sandefur</u>	Title <u>Director EHT & S</u>	Phone (with area code) <u>602-284-0280</u>

Note: This certification is not an application for an operating permit. At a minimum, the appropriate application form(s) must be submitted requesting an operating permit. The application must be submitted in accordance with the requirements of this permit.

The completed certification shall be delivered to East Tennessee Permit Program and the Environmental Field Office at the addresses listed below no later than thirty (30) days after the air contaminant source is started-up.

East Tennessee Permit Program
 Division of Air Pollution Control
 9th Floor, L & C Annex
 401 Church Street
 Nashville, TN 37243-1531

Knoxville Environmental Field Office
 Division of Air Pollution Control
 3711 Middlebrook Pike
 Knoxville, TN 37921

End of Conditions

Emission Summary

Permit Number: 966713P

Source Status: New ☒ Modification ☐ Expansion ☐ Relocation ☐

Permit Status: New ☒ Renewal ☐

PSD ☐ **NSPS** ☒ **NESHAPs** ☐ **Previous Permit Number:** Construction _____ Operating _____

	Pounds/Hour			Tons/Year				Date of Data	*	Applicable Standard 1200-03-
	Actual	Potential	Allowable	Actual	Potential	Allowable	Net Change			
TSP	0.03	0.03	0.03	0.01	0.01	0.01	+0.01	11/9/12	*	09-.03(8) & 40 CFR 60.4205(a)
SO ₂	0.50	0.50	0.50	0.13	0.13	0.13	+0.13	11/9/12	*	14-.01(3)
CO	0.20	0.20	0.20	0.05	0.05	0.05	+0.05	11/9/12	*	09-.03(8) & 40 CFR 60.4205(a)
VOC	0.81	0.81	0.81	0.20	0.20	0.20	+0.20	11/9/12	*	09-.03(8) & 40 CFR 60.4205(a)
NO _x	0.81	0.81	0.81	0.20	0.20	0.20	+0.20	11/9/12	*	09-.03(8) & 40 CFR 60.4205(a)
CO ₂ e	0.75	0.75	0.75	0.19	0.19	0.19	+0.19	11/9/12	*	40 CFR 98

* - Source of data

The emission factors for TSP, CO, VOC, & NO_x were taken from the actual exhaust during a 5-mode test by the manufacturer, Generac.

Per agreement letter dated January 21, 2013, the company has agreed to a limit of 0.50 lb/hr and 0.13 tpy for SO₂.

PERMITTING PROGRAM: HLC

DATE: 1/28/2013